ADDENDUM #01 October 29, 2025

TO CONTRACT DOCUMENTS FOR: Project #CP241934 – Memorial Stadium Facilities –

SEZ Recruiting Room Fitout

ADVERTISEMENT DATE: 10/06/2025

PREPARED FOR: The Curators of the University of Missouri

CONSULTANT: Simon Oswald Associates, Inc.

2801 Woodard Drive, Suite 103

Columbia, MO 65202 (573) 443-1407

The contract documents for the above noted project and the work covered thereby and herein modified.

GENERAL INFORMATION:

A non-mandatory prebid meeting was held on October 16, 2025. The sign-in sheet of attendees is attached for reference.

In response to a bidder question, an example graphic is attached to illustrate the concept of the black and gray tiger stripes for the construction fence referenced in the Special Conditions paragraph 8.b.2.

PROJECT MANUAL:

Revise the following specification sections as follows:

- 1) Specification Table of Contents: **CLARIFICATION** with the inclusion of the 1.E.6 Commissioning Plan, the section 1.E.6 in the Table of Contents shall be updated to reflect "COM 1/15" for clarifying the total number of pages in the specification.
- 2) Specification 1.E Special Conditions: **REVISE** Special Conditions paragraph 3.c.5 to read "Mechanical work shall consist of new ductwork and new VAV boxes for the additional enclosed building space. Additionally, the work includes a new supply fan array, SF-1, in existing AHU-1."
- 3) Specification 1.E.6 Commissioning Plan: **REPLACE** 1.E.6 Commission Plan specification in its entirety as the original specification was a two-page placeholder until the final Commissioning Plan was received.
- 4) Specification 07 2100 Thermal Insulation: **REPLACE** 07 2100 Thermal Insulation specification in its entirety as the original paragraph 2.3 Spray Polyurethane Foam Insulation is removed from the specification since it is included in the 07 2119 Foamed-In-Place Insulation specification.
- 5) Specification 07 2119 Foamed-In-Place Insulation: **REPLACE** 07 2119 Foamed-In-Place Insulation specification in its entirety. Revise paragraph 2.1 Closed-Cell Spray Polyurethane Foam Insulation to reflect a list of manufacturers still producing the spray foam product.

DRAWINGS:

Revise the following Drawing Sheets as follows:

- 1) Drawing sheet G0.2: **REPLACE** sheet G0.2 dated 10/02/2025 in its entirety with revised sheet G0.2 dated 10/29/2025 attached. Revise Use of Premises Keyed Note 04 to clarify the Heavy Duty Protection Mats will be Owner Furnished Owner Installed. Revise Use of Premises Keyed Notes to add note 05 for plastic barrier to protect existing walls not receiving work. Revise Overall Recruiting Room Plan to add keyed note 05 for locations of plastic construction barrier to protect existing walls.
- 2) Drawing sheet S001: **REPLACE** sheet S001 dated 10/02/2025 in its entirety with revised sheet S001 dated 10/29/2025 attached. Revise Code References to reflect IBC 2024.
- 3) Drawing sheet S002: **REPLACE** sheet S002 dated 10/02/2025 in its entirety with revised sheet S002 dated 10/29/2025 attached. Revise Code References to reflect IBC 2024 and add Seismic Design Data.
- 4) Drawing sheet S120: **REPLACE** sheet S120 dated 10/02/2025 in its entirety with revised sheet S120 dated 10/29/2025 attached. Revise sheet to add detail 7 for Stepped Footing Detail if required for where the existing stormwater piping enters the South End Zone.
- 5) Drawing sheet A102: **REPLACE** sheet A102 dated 10/02/2025 in its entirety with revised sheet A102 dated 10/29/2025 attached. Revise Keyed Notes D01 and D20 to clarify the overhead doors are to be salvaged and returned to the Owner.
- 6) Drawing sheet A601: **REPLACE** sheet A601 dated 10/02/2025 in its entirety with revised sheet A601 dated 10/29/2025 attached. Revise Wall Section 04 and Head Detail 08 to clarify metal wall panel at top of wall and site concrete at base of wall of Detail 04. Revise Detail 10 to clarify vapor barrier overlap requirements. Revise sheet to eliminate Detail 09 which does not apply.
- 7) Drawing sheet A701: **REPLACE** sheet A701 dated 10/02/2025 in its entirety with revised sheet A701 dated 10/29/2025 attached. Revise sheet to eliminate details 02 and 05 that are not applicable. Revise Detail 03 to clarify metal wall panel at top of wall. Revise Elevation 06 to provide dimensions of openings and panel configuration size.
- 8) Drawing sheet MED102: **REPLACE** sheet MED102 dated 10/02/2025 in its entirety with revised sheet MED102 dated 10/29/2025 attached. Revise Keyed Note 01 to clarify light fixtures are to be salvaged and returned to the Owner.
- 9) Drawing sheet E102: **REPLACE** sheet E102 dated 10/02/2025 in its entirety with revised sheet E102 dated 10/29/2025 attached. Revise Lighting Plan to clarify location of wall mounted light fixture in Table Storage S006E. Revise Overall Electrical Plan to update pathway for conduit, conductors and breakers for the new VAV boxes from the East side Electrical room and clarify scope for new speaker wiring.
- 10) Drawing sheet E502: **REPLACE** sheet E502 dated 10/02/2025 in its entirety with revised sheet E502 dated 10/29/2025 attached. Revise sheet to clarify the existing electrical Panelboard for the new breakers for the new VAV boxes.
- 11) Drawing sheet P102: **REPLACE** sheet P102 dated 10/02/2025 in its entirety with revised sheet P102 dated 10/29/2025 attached. Revise sheet to clarify the locations of trench drains, TD-1.

ATTACHMENTS:

The following attachments are to replace the original version included in the bid documents as described above:

- a. Pre-Bid Meeting Attendance Record (3 pages)
- b. Construction fence black and gray tiger stripes graphic for reference (1 page)
- c. Section 1.E.6 Commissioning Plan (15 pages)
- d. Section 07 2100 Thermal Insulation (6 pages)
- e. Section 07 2119 Foamed-In-Place Insulation (3 pages)
- f. Drawing Sheet G0.2 Use of Premises Plan (sheet 36"x48")
- g. Drawing Sheet S001 General Notes (sheet 36"x48")
- h. Drawing Sheet S002 Special Inspections (sheet 36"x48")
- i. Drawing Sheet S120 Recruitment Room Renovations (sheet 36"x48")
- j. Drawing Sheet A102 Field Level Recruiting Room Demo (sheet 36"x48")
- k. Drawing Sheet A601 Details (sheet 36"x48")
- 1. Drawing Sheet A701 Door & Frame Type & Schedule (sheet 36"x48")
- m. Drawing Sheet MED102 Field Level Recruiting MEP Demolition Plan (sheet 36"x48")
- n. Drawing Sheet E102 Recruiting Room Electrical Plans (sheet 36"x48")
- o. Drawing Sheet E502 Electrical Schedules and Riser (sheet 36"x48")
- p. Drawing Sheet P102 Field Level Recruiting Plumbing & Fire Protection Plan (sheet 36"x48")

END OF ADDENDUM #1

October 16, 2025 CP241934 Memorial Stadium Facilities - SEZ Recruiting Room Fitout

UNIVERSITY OF MISSOURI PREBID MEETING ATTENDANCE RECORD

*** The information on these pages will be posted publicly on a University of Missouri website ***

Name, Company, Address, Email and Phone Number	General Contractor Yes/No	Sub- Contract or Yes/No	Material Supplier Yes/No	MBE Yes/No	SDVE Yes/No	WBE Yes/No	DBE Yes/No
JOHN MOON MUPDEC							
Zach. Schulte Qunited mech serv. com							
Zach Schulte United Mechanical Services	90	yes	20	No	no	No	20
JEFF BENDLE 314-402-8143	NO	No	Yen	NO	NO	NO	NO
Curtis Tolson 2US	W	As	Nø	No	No	NO	146
Jostin Reynolds Siscal Contracting Com Justine Siscal contracting com 573-303-7298	Jes	NO	NO	NO	NO	NO	ND
Wyatt Ahart Kaiser Electric of Centrel MU wahart@kaiser centralmo.com 573-55le-less	No	Yes	No	NO	Mu	NU	wo

October 16, 2025 CP241934 Memorial Stadium Facilities - SEZ Recruiting Room Fitout

UNIVERSITY OF MISSOURI PREBID MEETING ATTENDANCE RECORD

*** The information on these pages will be posted publicly on a University of Missouri website ***

Name, Company, Address, Email and Phone Number	General Contractor Yes/No	Sub- Contract or Yes/No	Material Supplier Yes/No	MBE Yes/No	SDVE Yes/No	WBE Yes/No	DBE Yes/No
KEVIN HARVEY-REINHARDT CONSTRUCTION (573) (682-5505) 2401 BERNADETTE BRIVE COLUMBIA, MO 65203 Estimating Reinhardt construction Ic. com	У	N	N	N	N	N	N
Scott Fette (513)443 2488 mailbox Q ylcaum.com JLCRUM 1312 N CREASY SPRINGS COLUMNA NO 65202	N	4	2	٢	Y	2	2
RELLY HEWVEM BOUNG RHEQUEM BOUNG R RAVER CETY KHEQUEM BOUNG R LG46 AMERECAN SETTON DR ASHUM NO GTUIO	~ X	N	N	N	N	N	N
KELLY HAWKINS admin@ Scaksassociates.com 627 N. ROCCIONS Centralia, MO	7	N	N	N	N	Y	N
Kathy Ungles Mu PD+C							
Nick Britten MU PD+C							
Eric Gooding MU PD+C							

October 16, 2025 CP241934 Memorial Stadium Facilities - SEZ Recruiting Room Fitout

UNIVERSITY OF MISSOURI PREBID MEETING ATTENDANCE RECORD

*** The information on these pages will be posted publicly on a University of Missouri website ***

Name, Company, Address, Email and Phone Number	General Contractor Yes/No	Sub- Contract or Yes/No	Material Supplier Yes/No	MBE Yes/No	SDVE Yes/No	WBE Yes/No	DBE Yes/No
Brad Armstrong Havold G. Butzer, Inc. 721 Wicker Ln Jamo 65109 Brad A @ HGButzer. com 573-636-4115	N	4	N	\sim	N	N	N
BRAD STEGEMANN-SOA Stegemann @ SOA-Inc. Com	N	n	n	N	N	N	N
Shans Augh. Timberlake Shane@timberlakeenginering.com (573)875-4365	~	~	N	Y	~	~	N

(19) 50ft x 5ft6





CP241934 Memorial Stdium SEZ Rcruitg Rm Commissioning Check List

Ve	rified by:		Date	Coord	Documentation O	wner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
1						
Building System Commissioning						
Commissioning Agent - Conduct pre-installation meetings per specifications.						<u>✓</u>
24119			.			
Selective Demolition						
Hold Pre-Installation Meetings as specified					Meeting Minutes	<u> </u>
Protect walls, ceilings, floors and other existing finish work that are to remain during demolition						
33000						
Cast-in-Place Concrete						
Hold Pre-Concrete conference as specified					Meeting Minutes	<u> </u>
Provide a Copy Of Field Cured Concrete Cylinder Test Report to Owner's Rep Prior to Stripping Any Load Bearing Formwork					Test Report From Independe Testing Lab	nt
Submit concrete mix designs prepared by a qualified testing laboratory for approval prior to placement.					mix design reports	
33536			•			
Polished Concrete Floor Finishing						
Perform Field Quality Control section of specifications					Test Report	<u> </u>
51200		·	.		1	
Structural Steel						
Hold Structural Steel Pre-Erection Conference as specified					Meeting Minutes	<u> </u>

	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
Provide welder qualification report for each welder on site					Welder Qualifications	✓
53000 Steel Deck			<u>, </u>	<u>'</u>		
Provide welder qualification report for each welder on site					Welder Qualifications	✓
Verify welds have been coated with zinc-rich touch- up paint.						
54000 Cold-Formed Metal Framing			I	<u> </u>	•	
Hold Pre-Installation Meetings as specified					Meeting Minutes	✓
Perform Field Quality Control section of specifications					Test Report	<u> </u>
55000 Metal Fabrications			I	<u> </u>	•	
Provide welder qualification report for each welder on site					Welder Qualifications	✓
55213 Pipe and Tube Railings	<u> </u>		I			
Provide welder qualification report for each welder on site					Welder Qualifications	✓
57500		1			1	
Decorative Formed Metal (CL-1, WP-1)						
Provide welder qualification report for each welder on site					Welder Qualifications	✓

Ve	rified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
72726						
Fluid-Applied Membrane Air Barriers						
Perform Field Quality Control section of specifications					Test Report	✓
74213				<u>'</u>		
Formed Metal Wall Panels						
Perform Field Quality Control section of specifications.					field report	<u> </u>
75419		<u> </u>	<u> </u>	•	L	
Polyvinyl-Chloride (PVC) Roofing						
Hold Pre-Installation Meetings as specified					Meeting Minutes	✓
Perform Final Roof Inspection (Manufacturer's Rep) Per Field Quality Control section of Spec.					field report	<u> </u>
78413		1			1	
Penetration Firestopping						
Do not enclose firestopping with other construction until inspection has been completed.						
78443		1	!		1	
Joint Firestopping						
Hold preinstallation meetings as specified					Meeting Minutes	<u> </u>
Perform Field Quality Control section of specifications.				1	Test Report	<u> </u>
81113						
Hollow Metal Doors and Frames		•	_			
Inspect Fire Doors					itemized list of doors	\checkmark
				1		

	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
81416						
Flush Wood Doors						
Inspect Fire Doors					Door List	✓
83513	<u>I</u>	<u> </u>			<u> </u>	
Multipanel Folding Aluminum- Framed Glass Doors						
Perform Field Quality Control section of specifications					Test Report	<u> </u>
84113		•	I		· I	
Aluminum-Framed Entrances and Storefronts						
Build Mockups as specified					Inspection Report	<u>✓</u>
Perform Field Quality Control section of specifications					Test Report	✓
87100		1	<u> </u>		1	
Door Hardware						
Verify that all fire doors close and latch positively					test report	<u> </u>
88000		1	<u> </u>	ı	•	
Glazing						
Hold Pre-Installation Meetings as specified					Meeting Minutes	✓
Wash clear glass on both faces not more than 4 days prior to punch list inspection						

	Verified by:	Verified by:		Coord	Documentation	Owner Witness	
Commissioning Items by CSI Division	Name	Firm	Date compl	Initial	Required	Required	
90561							
Topical Moisture Mitigation System							
Perform Field Quality Control section of specs					Test Report	✓	
93013	<u> </u>						
Ceramic Tiling							
Furnish Extra Material as specified					Transmittal	✓	
Hold Pre-Installation Meetings as specified				1	Meeting Minutes	<u>✓</u>	
95113	<u> </u>	1					
Acoustical Panel Ceilings							
Ensure that all debris is removed from above ceiling tiles during final above ceiling inspection.						\checkmark	
Furnish Extra Material as specified					Transmittal	✓	
Hold Pre-Installation Meetings as specified					Meeting Minutes	<u> </u>	
96513	<u>l</u>	<u> </u>					
Resilient Base and Accessories							
Construct mock-ups per specifications					Inspection Report	✓	
Furnish Extra Material as specified					Transmittal		

	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
96516						
Resilient Sheet Flooring						
After installation maintain ambient temperature of not less than 55 deg F or more than 95 deg F.						
Clean, seal and wax according to manufacturer's instructions. Document the processes and products used for initial sealing.						<u> </u>
Furnish Extra Material as specified					Transmittal	<u> </u>
Perform pH, Chloride (moisture) and bond tests per manufacturer. Do not proceed until all manufacturing requirements are met.					test reports	<u> </u>
99113	•	•	•	•	•	
Exterior Painting						
Periodically Check Wet Film Thickness To Assure Conformance With Manufacturer's Requirements To Achieve Dry Film Thickness					field report	<u> </u>
Periodically Check Wet Film Thickness To Assure Conformance With Manufacturer's Requirements To Achieve Dry Film Thickness					field report	<u> </u>
Touch up and restore damaged or defaced surfaces prior to substantial completion						
99123	•	•	<u> </u>		•	
Interior Painting						
Furnish Extra Material as specified					Transmittal	
Periodically Check Wet Film Thickness To Assure Conformance With Manufacturer's Requirements To Achieve Dry Film Thickness per Field Quality Control section of spec					field report	✓

	Verified by:		Date	Coord	Documentation	Owner Witness	
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required	
102600							
Wall and Door Protection							
Furnish Extra Material as specified					Transmittal	✓	
102800					1		
Toilet, Bath, and Laundry Accessories							
Adjust and clean per specifications.							
211300					1		
Wet-Pipe Sprinkler Systems							
Coordinate operation with fire alarm test. Test per Field Quality Control					Test certification NFPA1	3	
Fill water system and flush system							
Provide extra material as required by code and specs					Transmittal	<u> </u>	
Verify all temperature ratings							
230500	<u> </u>						
Common Work Results for HVAC							
Hold MEP pre-installation meeting(s).					Meeting Minutes	✓	
Perform Field Quality Control Section of specification					Test Report	<u> </u>	

V	erified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
230553						
Identification for HVAC Piping and Equipment						
Install pipe markers per specifications						
230593		1			<u> </u>	
Test-Adjust-Balance						
Ensure pre-test requirements as specified in paragraph 1.2C have been completed						
Hold Pre-Balancing Conference as specified					Meeting Minutes	<u>✓</u>
Mark equipment settings including central positions, value indicators, fan speed control levers, etc.						
Notify Owner's Representative 14 days prior to the scheduled date for balancing the system.					written notification	
230713					<u> </u>	
Duct Insulation						
Perform Field Quality Control section of specifications					Test Report	✓
Verify required mechanical fasteners are installed per specifications.						
Verify that duct systems are tested prior to insulating						
230900				ı	•	
Control Systems						
Ensure Control Transformer amps are within specifications					Test Report	<u> </u>


	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
Ensure shipping material has been removed from thermostats and other control devices						
Post laminated control diagram in mechanical room						
Verify all field devices provided by contractor are terminated						
Verify all panel covers are installed						
232300	<u> </u>	<u> </u>			1	
Refrigerant Piping						
Leak test per Field Quality Control section of specifications					Test Report	✓
Provide start-up service per specifications						
233113		1				
Metal Ducts						
test for duct leakage per spec. To a leakage class of 4, at least. Ducts shall meet leakage requirement prior to testing and balancing					test report	<u>✓</u>
233300						
Air Duct Accessories						
Demonstrate Proper Operation of All Fire Dampers per NFPA-90A.					test report	<u> </u>
Perform Field Quality Control section of specifications					Test Report	<u> </u>

	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
233423						
HVAC Power Ventilators						
Check Fan rotation and Amp Draw					Test Report	✓
233600	<u> </u>	<u> </u>				
Air Terminal Units						
Notify owner's rep after fully installing a representative unit (in-place mockup) for approval. Coordinate and cooperate with owner's commissioning of the boxes.						
Perform Field Quality Control section of spec					Test Report	
Perform Startup Service section of spec					Startp Report	✓
Packaged Compressor and Condenser						
236200 Packaged Compressor and Condenser Units Perform Field Quality Control section of spec				1	Test Report	
Packaged Compressor and Condenser Units					Test Report Startup Report	
Packaged Compressor and Condenser Units Perform Field Quality Control section of spec Perform Startup Service section of spec Provide factory training per Demonstration section						<u></u>
Packaged Compressor and Condenser Units Perform Field Quality Control section of spec					Startup Report	V
Packaged Compressor and Condenser Units Perform Field Quality Control section of spec Perform Startup Service section of spec Provide factory training per Demonstration section of spec					Startup Report	✓
Packaged Compressor and Condenser Units Perform Field Quality Control section of spec Perform Startup Service section of spec Provide factory training per Demonstration section of spec 237313					Startup Report	<u>✓</u>

	Verified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
Perform Startup Service section of spec					Startup Report	✓
260519					<u> </u>	
Low-Voltage Electrical Power Conductors and Cables						
Perform independent tests per spec, including megohm/high pot tests					test report	✓
260526			<u> </u>	<u> </u>	<u> </u>	
Grounding and Bonding for Electrical Systems						
Perform resistance test as described in "Field Quality Control" section of spec					test report	✓
260553		•			•	
Identification for Electrical Systems						
Ensure identification devices are applied per specifications						
260573				•		
Arcflash Study						
Factory certified technician to set electronic overcurrent devices to approved coordination study setpoints					Inspection Report	✓
Perform 'Testing' section of specifications					Test Report	V
Place arcflash labels on equipment as specified						✓
Train owners representatives in setting of overcurrent devices					Sign-up Sheet	✓

Ve	rified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
260923						
Lighting Control Devices						
Perform Field Quality Control section of specifications					field report	✓
Provide factory training per Demonstration section of spec					Sign In Sheet	<u> </u>
262213		<u> </u>	<u> </u>		<u> </u>	
Low-Voltage Distribution Transformers						
Test transformer per Field Quality Control section of specifications					test results	<u> </u>
262416		1	<u> </u>			
Panelboards						
Perform checks per "Field Quality Control" section of spec					Test Reports	<u> </u>
262726		•	<u> </u>			
Wiring Devices						
Operate All Devices per "Field Quality Control" section of spec to verify correct operation					Test Report	<u> </u>
262816		1				
Enclosed Switches and Circuit Breakers						
Perform tests per "Field Quality Control" section of spec					Test Report	<u> </u>
265119					1	
LED Interior Lighting						
Perform Field Quality Control section of specifications					Test Report	✓

V	erified by:		Date	Coord	Documentation	Owner Witnes
Commissioning Items by CSI Division	Name	Firm	compl	Initial	Required	Required
265213						
Emergency and Exit Lighting						
Perform 90 minute battery test or generator test					Test Report	✓
Perform Field Quality Control section of specifications					Test reports	✓
283111		•	•	•	•	
Digital, Addressable Fire-Alarm System						
Pretest system and work out all bugs. Final test should not have bugs to work through					PreTest Checklist	
Provide factory training Per demonstration section of specifications					Sign-up Sheet	✓
Test System Fully and provide certification				1	Test Report; NFPA72 Certification	<u>✓</u>



Construction Management Checklist for Energizing Utilities (Contractor to initial each item upon completion and provide completed form to the Owner's Representative prior to energizing utility)

Water – turned on to the first valve past Energy Management's last valve.

	 Review all piping and equipment being turned on for proper installation and completed testing Insulation installed (preferred but not required) Meter properly installed, working, and in readable location. Contractor has swabbed out with chlorine all piping from the backflow preventer to the source while installing.
	All bacteriological tests have been completed and passed. Backflow preventer installed and tested. (will need water pressure to test) Pressure test completed in piping being turned on. Contractor has method to communicate "Services On" to other contractor personnel and Owner's personnel. Consultant has signed off
Stear	n – turned on to the first valve past Energy Management's last valve.
	Review all piping, equipment, valves, reducing stations, relief valves, etc. for proper installation and complete testing. Piping protected from the weather. Insulation must be installed. All hangers and bolts have been installed. Meter installed, working and in readable location. (Don't need metasys to turn on.) All needed traps are installed and able to be tested as they are turned on. Condensate system is installed and operating including the pumping system. Pressure test completed in piping being turned on. Contractor has method to communicate "Services On" to other contractor personnel and Owner's personnel. Consultant has signed off ensate – turned on to the first valve past Energy Management's last valve.
	Review all piping and equipment being turned on for proper installation and completed testing. Piping protected from the weather. Insulation installed (preferred but not required) Pressure test completed in piping being turned on. Contractor has method to communicate "Services On" to other contractor personnel and Owner's personnel. Consultant has signed off ric – turned on to the first breaker past 13.8kV transformer.
Chil	Review all wiring and equipment being turned on for proper installation and completed testing GFCI set and tested. Breakers set and tested. All needed permanent grounds are installed. Meter installed, working and in readable location. Main switchgear protected from the weather. Contractor has method to communicate "Services On" to other contractor personnel and Owner's personnel. Consultant has signed off lled Water – turned on to the first valve inside of building.
	Review all piping and equipment being turned on for proper installation and completed testing. Pressure test completed in piping being turned on. Insulation must be installed. Meter installed, working and connected to Metasys. Building pump and automatic isolation/control valve must be installed and under control. If chillers are installed, automatic loop pump isolation must be installed. Control valves must be installed and automatically controlled on all loads. Contractor has method to communicate "Services On" to other contractor personnel and Owner's personnel. Consultant has signed off

SECTION 07 2100 - THERMAL INSULATION

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. Section Includes:
 - 1. Foundation wall insulation (supporting backfill).
 - 2. Foam plastic board insulation.
 - 3. Glass-fiber blanket insulation.
 - 4. Cladding attachment system.
- B. Related Sections:
 - 1. Section 04 2000 "Unit Masonry" for installation of insulation installed in cavity walls.

1.3 ACTION SUBMITTALS

A. Product Data: For each type of product indicated.

1.4 INFORMATIONAL SUBMITTALS

- A. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency, for each product.
- B. Research/Evaluation Reports: For foam-plastic insulation, from ICC-ES.
- C. NFPA 285 Testing Data for wall assemblies with cladding attachment system.

1.5 QUALITY ASSURANCE

A. Surface-Burning Characteristics: As determined by testing identical products according to ASTM E 84 by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Protect insulation materials from physical damage and from deterioration due to moisture, soiling, and other sources. Store inside and in a dry location. Comply with manufacturer's written instructions for handling, storing, and protecting during installation.
- B. Protect foam-plastic board insulation as follows:

- 1. Do not expose to sunlight except to necessary extent for period of installation and concealment.
- 2. Protect against ignition at all times. Do not deliver foam-plastic board materials to Project site before installation time.
- 3. Quickly complete installation and concealment of foam-plastic board insulation in each area of construction.

PART 2 - PRODUCTS

2.1 FOUNDATION WALL INSULATION

- A. Extruded-Polystyrene Board Insulation: Rigid, cellular polystyrene thermal insulation formed from polystyrene base resin by an extrusion process using hydrochlorofluorocarbons as blowing agent to comply with ASTM C 578 for type and with other requirements indicated below:
 - 1. Type IV, 1.60-lb/cu. ft. minimum density, unless otherwise indicated.
 - 2. Surface-Burning Characteristics: Maximum flame-spread and smoke-developed indices of 75 and 450, respectively.
 - 3. Foundation wall perimeter insulation shall be 2-inches thick, unless noted otherwise.
- B. Molded Polystyrene Board, Type IX, at Contractor's Option: ASTM C578, Type IX, 25-psi minimum compressive strength.
 - 1. <u>Manufacturers:</u> Subject to compliance with requirements, provide products by one of the following:
 - a. ACH Foam Technologies, Inc.
 - b. Atlas Molded Products; a Division of Atlas Roofing Corporation.
 - c. DiversiFoam Products.
 - d. Insulfoam; Carlisle Construction Products.
 - e. Plymouth Foam, Inc.
 - 2. Foundation wall perimeter insulation shall be 2-inches thick by 24 -inches depth, unless noted otherwise.

2.2 FOAM-PLASTIC BOARD INSULATION

- A. Polyisocyanurate Board Insulation: ASTM C 1289, foil faced, Type I, Class 1 or 2; with maximum flame-spread and smoke-developed indexes of 75 and 450, respectively, per ASTM E 84.
 - 1. <u>Manufacturers</u>: Subject to compliance with requirements, provide products by one of the following:
 - a. Atlas Molded Products.
 - b. Carlisle Coatings and Waterproofing.
 - c. Dow Chemical Company (The).
 - d. Firestone Building Products.
 - e. Hunter Panels.
 - f. Johns Manville.
 - g. R-Max, Inc.

- 2. Rigid insulation under wall panels shall be foil-faced polyisocyanurate board 2-1/2 inches thick, unless noted otherwise.
- 3. Insulation shall have been tested with specified cladding attachment system to provide an NFPA 285 compliant assembly.
- B. Adhesive for Bonding Insulation: Product with demonstrated capability to bond insulation securely to substrates without damaging insulation and substrates.

2.3 GLASS-FIBER BLANKET INSULATION

- A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 - 1. CertainTeed Corporation.
 - 2. Guardian Fiberglass, Inc.
 - 3. Johns Manville.
 - 4. Knauf Fiber Glass.
 - 5. Owens Corning.
- B. Unfaced, Glass-Fiber Blanket Insulation: ASTM C 665, Type I (blankets without membrane facing); consisting of fibers; with maximum flame-spread and smoke-developed indexes of 25 and 50, respectively; passing ASTM E 136 for combustion characteristics.
- C. Where glass-fiber blanket insulation is indicated by the following thicknesses or shown to fill entire stud cavity, provide blankets in batt or roll form with thermal resistances indicated:
 - 1. 5-1/2 inches thick with a thermal resistance of 19 deg F x h x sq. ft./Btu at 75 deg F.

2.4 INSULATION FASTENERS

- A. Adhesively Attached, Spindle-Type Anchors: Plate welded to projecting spindle; capable of holding insulation of thickness indicated securely in position indicated with self-locking washer in place; and complying with the following requirements:
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. AGM Industries, Inc.; Series T TACTOO Insul-Hangers.
 - b. Eckel Industries of Canada; Stic-Klip Type N Fasteners.
 - c. Gemco; Spindle Type.
 - 2. Plate: Perforated galvanized carbon-steel sheet. 0.030 inch thick by 2 inches square.
 - 3. Spindle: Copper-coated, low carbon steel; fully annealed; 0.105 inch in diameter; length to suit depth of insulation indicated.
- B. Anchor Adhesive: Product with demonstrated capability to bond insulation anchors securely to substrates indicated without damaging insulation, fasteners, and substrates.
 - 1. Products: Subject to compliance with requirements, provide one of the following:
 - a. AGM Industries. Inc.: TACTOO Adhesive.
 - b. Eckel Industries of Canada; Stic-Klip Type S Adhesive.
 - c. Gemco; Tuff Bond Hanger Adhesive.

2.5 CLADDING ATTACHMENT SYSTEM

- A. Polyester and vinyl ester bioresin matrix with recycled materials, fire retardant additives and integral continuous metal inserts the length of profile. Reinforce girts with glass strand rovings used internally for longitudinal strength and continuous strand glass mats or stitched reinforcements used internally for transverse strength.
 - 1. Products: Subject to compliance with requirements, provide the following:
 - a. Advanced Architectural Products (A2P), SMART ci 2-in-1 System.
 - b. Armatherm; Z Girt.
 - 2. Girt Depth: To match rigid insulation thickness.
 - 3. Spacing: 24 inches on center, applied horizontally and secured to each framing stud.
 - 4. Provide manufacturer's standard continuous 16-gauge galvanized steel continuous insert for engagement of fasteners into metal framing.
 - 5. Install integral with foil-faced, polyisocyanurate board insulation.
 - 6. Provide manufacturer's standard integral three-point compression seal to prevent insulation panels from dislodging.
 - 7. Provide manufacturer's standard integral anti-siphon grooves on exterior and interior flanges of girt members.
 - 8. Provide manufacturer's standard spline seals for adjacent insulation units into profile of girt members.
 - 9. Cladding attachment system shall have passed NFPA 285 assembly testing in conjunction with foil-faced polyisocyanurate board insulation and cladding specified.

PART 3 - EXECUTION

3.1 PREPARATION

A. Clean substrates of substances that are harmful to insulation or that interfere with insulation attachment.

3.2 INSTALLATION OF BELOW-GRADE INSULATION

- A. On footing and foundation wall surfaces, set foundation wall insulation board units loosely laid according to manufacturer's written instructions.
 - 1. If not otherwise indicated, extend insulation a minimum of 24 inches below exterior grade line.

3.3 INSTALLATION, GENERAL

- A. Comply with insulation manufacturer's written instructions applicable to products and applications indicated.
- B. Install insulation that is undamaged, dry, and unsoiled and that has not been left exposed to ice, rain, or snow at any time.
- C. Extend insulation to envelop entire area to be insulated. Cut and fit tightly around obstructions and fill voids with insulation. Remove projections that interfere with placement.

D. Provide sizes to fit applications indicated and selected from manufacturer's standard thicknesses, widths, and lengths. Apply single layer of insulation units to produce thickness indicated unless multiple layers are otherwise shown or required to make up total thickness.

3.4 INSTALLATION OF INSULATION FOR METAL-FRAMED CONSTRUCTION

- A. Apply insulation units to substrates by method indicated, complying with manufacturer's written instructions. If no specific method is indicated, bond units to substrate with adhesive or use mechanical anchorage to provide permanent placement and support of units.
- B. Glass Fiber: Install in cavities formed by framing members according to the following requirements:
 - 1. Use insulation widths and lengths that fill the cavities formed by framing members. Where more than one length is required to fill the cavities, provide lengths that will produce a snug fit between ends.
 - 2. Place insulation in cavities formed by framing members to produce a friction fit between edges of insulation and adjoining framing members.
- C. Miscellaneous Voids: Install insulation in miscellaneous voids and cavity spaces where required to prevent gaps in insulation using the following materials:
 - 1. Spray Polyurethane Insulation: Apply according to manufacturer's written instructions.

3.5 INSTALLATION OF CLADDING ATTACHMENT SYSTEM

- A. Install cladding attachment system framing in accordance with manufacturer's written installation instructions.
- B. Do not overtighten screw fasteners to avoid crushing sheathing and damaging air barrier membrane.
- C. Install cladding attachment system framing to fill in exterior continuous insulation spaces without gaps or voids. Do not compress insulation panels.
- D. Trim insulation neatly to fit spaces and insulate miscellaneous gaps and voids.
- E. Seal gaps, voids or penetrations with expandable foam sealant on exterior side of insulation.

3.6 PROTECTION

A. Protect installed insulation from damage due to harmful weather exposures, physical abuse, and other causes. Provide temporary coverings or enclosures where insulation is subject to abuse and cannot be concealed and protected by permanent construction immediately after installation.

END OF SECTION 07 2100

SECTION 07 2119 - FOAMED-IN-PLACE INSULATION

PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Closed-cell spray polyurethane foam insulation and ignition barrier.
 - Accessories.
- B. Related Requirements:
 - 1. Section 07 2100 "Thermal Insulation" for foam-plastic board insulation.

1.2 ACTION SUBMITTALS

- A. Product Data:
 - 1. Closed-cell spray polyurethane foam insulation.
 - Accessories.

1.3 INFORMATIONAL SUBMITTALS

- A. Product Test Reports: For each product, for tests performed by qualified testing agency.
- B. Qualification Statements: For Installer.

1.4 QUALITY ASSURANCE

A. Installer Qualifications: An authorized representative who is trained and approved by manufacturer.

PART 2 - PRODUCTS

2.1 CLOSED-CELL SPRAY POLYURETHANE FOAM INSULATION

- A. Closed-Cell Spray Polyurethane Foam: ASTM C1029, Type II, minimum density of 1.5 lb/cu. ft. and minimum aged R-value at 1-inch thickness of 6.2 deg F x h x sq. ft./Btu at 75 deg F.
 - 1. Basis-of-Design: Subject to compliance with requirements, provide SPRAYTITE 158 Series by BASF Corporation, other available manufacturers offering acceptable equivalent products that may be incorporated into the Work include the following:
 - a. Bayer Material Science LLC.
 - b. Henry Company.
 - c. Huntsman Building Solutions.
 - d. SWD Urethane Company.

- 2. Surface-Burning Characteristics: Comply with ASTM E84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - a. Flame-Spread Index: 25 or less.
 - b. Smoke-Developed Index: 450 or less.
- 3. Fire Propagation Characteristics: Passes NFPA 285 testing as part of an approved assembly.

2.2 ACCESSORIES

- A. Primer: Material recommended by insulation manufacturer where required for adhesion of insulation to substrates.
- B. Ignition Barrier: Material providing a 15-minute minimum fire-ignition barrier.
 - 1. Ignition Barrier Coating: Fire-protective coating formulated for application over polyurethane foam plastics, compatible with insulation, and in compliance with ICC- ES AC377, Appendix X.
 - a. Basis-of-Design: Subject to compliance with requirements, provide Ure-K Spray-On-Systems by International Cellulose Corp., other available manufacturers offering acceptable equivalent products that may be incorporated into the Work include the following:
 - 1) Central Fiber LLC.
 - 2) GreenFiber.
 - 3) Hamilton Manufacturing Inc.
 - 4) Nu-Wool Co., Inc.
 - b. Color: Black, unless otherwise indicated.
 - 2. Surface-Burning Characteristics: Comply with ASTM E84; testing by a qualified testing agency. Identify products with appropriate markings of applicable testing agency.
 - a. Flame-Spread Index: 25 or less.
 - b. Smoke-Developed Index: 50 or less.

PART 3 - EXECUTION

3.1 PREPARATION

- A. Verify that substrates are clean, dry, and free of substances that are harmful to insulation.
- B. Priming: Prime substrates where recommended by insulation manufacturer. Apply primer to comply with insulation manufacturer's written instructions. Confine primers to areas to be insulated; do not allow spillage or migration onto adjoining surfaces.


3.2 INSTALLATION

- A. Comply with insulation manufacturer's written instructions applicable to products and applications.
- B. Spray insulation to envelop entire area to be insulated and fill voids.
- C. Apply in multiple passes to not exceed maximum thicknesses recommended by manufacturer. Do not spray into rising foam.
- D. Miscellaneous Voids: Apply according to manufacturer's written instructions.
- E. Install ignition barrier material.
 - 1. Do not cover insulation prior to any required spray foam insulation inspections.
- F. Apply barrier coatings in accordance with manufacturer's written instructions and to comply with requirements for listing and labeling for fire-propagation characteristics and surface-burning characteristics specified.
 - 1. Use equipment and techniques best suited for substrate and type of material applied as recommended by coating manufacturer.
 - 2. Apply coatings to prepared surfaces as soon as practical after preparation and before subsequent surface soiling or deterioration.
 - 3. Apply coatings to produce surface films without cloudiness, spotting, holidays, laps, brush marks, roller tracking, runs, sags, ropiness, or other surface imperfections. Produce sharp lines and color breaks.

3.3 PROTECTION

A. Protect installed insulation from damage due to harmful weather exposures, physical abuse, and other causes.

END OF SECTION 07 2119



Bradley J. Stegemann - Architect License No. A-2008015243

THE PROFESSIONAL ARCHITECT'S
SEAL ON THIS DRAWING HAS
BEEN AFFIXED IN ACCORDANCE
WITH THE REQUIREMENTS OF
CHAPTER 327, RSMO. IN AFFIXING
THIS SEAL, THE ARCHITECT WORK SHOWN ON THIS DRAWING
ONLY, AND HEREBY DISCLAIMS
ANY AND ALL RESPONSIBILITY FOR
OTHER PROJECT DRAWINGS NOT
DIRECTLY BEARING THIS SEAL.

ISSUE FOR BID

G0.2

GR GENERAL REQUIREMENTS

GR-1 AS USED IN THESE GENERAL NOTES: "DRAWINGS" MEANS THE LATEST STRUCTURAL DESIGN DRAWINGS, UON. "SPECIFICATIONS" MEANS THE LATEST PROJECT SPECIFICATIONS, UON. "CONTRACT DOCUMENTS" IS DEFINED AS THE DESIGN DRAWINGS AND THE SPECIFICATIONS "SER" IS DEFINED AS THE STRUCTURAL ENGINEER OF RECORD FOR THE STRUCTURE IN ITS FINAL "DESIGN PROFESSIONALS" IS DEFINED AS THE OWNER'S ARCHITECT AND SER. "MEP" INCLUDES, BUT IS NOT LIMITED TO MECHANICAL, ELECTRICAL, PLUMBING, FIRE PROTECTION.

"CONTRACTOR" IS DEFINED TO INCLUDE ANY OF THE FOLLOWING: GENERAL CONTRACTOR AND THEIR SUBCONTRACTORS, CONSTRUCTION MANAGER AND THEIR SUBCONTRACTORS, STRUCTURAL STEEL FABRICATOR OR STRUCTURAL STEEL ERECTOR. "BASE BUILDING STRUCTURE" IS DEFINED AS THE STRUCTURAL FRAME DESIGNED BY THORNTON "STRUCTURE IN ITS FINAL CONDITION" MEANS ALL STRUCTURAL ELEMENTS SHOWN ON THE STRUCTURAL CONTRACT DOCUMENTS ARE INSTALLED AND COMPLETELY CONNECTED AND INSPECTED WITH NO OUTSTANDING NON-COMPLIANCE ISSUES. "DELEGATED DESIGN" MEANS A SCOPE OF WORK THAT MEETS PERFORMANCE CRITERIA ESTABLISHED IN THE CONTRACT DOCUMENTS AND IS TO BE COMPLETED BY THE CONTRACTOR'S LICENSED

"SERVICE LEVEL" LOADS ARE DEFINED AS NOMINAL OR UNFACTORED LOADS TO BE COMBINED USING

"STRENGTH LEVEL" LOADS ARE DEFINED AS FACTORED LOADS TO BE COMBINED USING STRENGTH

GR-2 THE CONTRACTOR IS RESPONSIBLE FOR COORDINATION OF THE STRUCTURAL WORK WITH THE ARCHITECTURAL, CIVIL, MEP CONTRACT DOCUMENTS, AS WELL AS ANY OTHER APPLICABLE TRADES.

ALLOWABLE STRESS LOAD COMBINATIONS

DESIGN LOAD COMBINATIONS

CONSTRUCTION OF THE STRUCTURE REACHES ITS FINAL CONDITION. GR-4 THE CONTRACTOR IS SOLELY RESPONSIBLE FOR THE DESIGN, INSTALLATION, AND REMOVAL OF TEMPORARY BRACING AND CONSTRUCTION SUPPORTS, FOR NEW AND EXISTING STRUCTURES, AS NECESSARY TO COMPLETE THE PROJECT. NO PORTION OF THE PROJECT WHILE UNDER CONSTRUCTION IS INTENDED TO BE STABLE IN THE ABSENCE OF THE CONTRACTOR'S TEMPORARY SUPPORTS AND BRACES. CONTRACTOR SHALL RETAIN A PROFESSIONAL ENGINEER LICENSED IN THE

GR-3 THE CONTRACTOR IS RESPONSIBLE FOR THE STABILITY OF THE STRUCTURE UNTIL THE

GR-5 THE SPECIFICATIONS ARE AN INTEGRAL PART OF THE CONTRACT DOCUMENTS AND SHALL BE USED IN CONJUNCTION WITH THE STRUCTURAL DRAWINGS.

STATE WHERE THE PROJECT IS LOCATED TO DESIGN TEMPORARY BRACING AND CONSTRUCTION

GR-6 THE CONTRACTOR SHALL VERIFY ALL EXISTING DIMENSIONS AND CONDITIONS AND COORDINATE WITH THE STRUCTURAL DRAWINGS, ARCHITECTURAL DRAWINGS, DRAWINGS FROM OTHER

CONSULTANTS, PROJECT SHOP DRAWINGS AND FIELD CONDITIONS.

GR-7 IN CASES OF CONFLICT BETWEEN DRAWINGS AND/OR SPECIFICATIONS AND OTHER DISCIPLINES OR EXISTING CONDITIONS, CONTRACTOR SHALL NOTIFY THE DESIGN PROFESSIONALS AND OBTAIN CLARIFICATION PRIOR TO BIDDING AND PROCEEDING WITH WORK.

GR-8 APPLY DETAILS, SECTIONS, AND NOTES ON THE DRAWINGS WHERE CONDITIONS ARE SIMILAR TO THOSE INDICATED BY DETAIL, DETAIL TITLE OR NOTE.

GR-9 ONLY USE DIMENSIONS INDICATED ON THE DRAWINGS. DO NOT SCALE DRAWINGS. GR-10 ASSUME EQUAL SPACING BETWEEN ESTABLISHED DIMENSIONS, IF NOT INDICATED ON DRAWINGS. GR-11 CENTERLINES OF COLUMNS AND FOUNDATIONS COINCIDE WITH GRID LINE INTERSECTIONS, UON. GR-12 CENTERLINES OF GRADE BEAMS AND WALLS COINCIDE WITH CENTERLINES OF FOUNDATIONS, UON. GR-13 CENTERLINES OF FRAMING MEMBERS COINCIDE WITH COLUMN CENTERLINES, UON.

GR-14 THE CONTRACTOR SHALL PROTECT EXISTING FACILITIES, STRUCTURES AND UTILITIES FROM

GR-15 THE CONTRACTOR SHALL VERIFY THAT CONSTRUCTION LOADS DO NOT EXCEED THE CAPACITY OF THE STRUCTURE AT THE TIME THE LOAD IS APPLIED.

GR-16 THE CONTRACTOR SHALL COORDINATE THE BOTTOM OF BASE PLATE ELEVATIONS WITH THE AS-BUILT TOP OF SUPPORT ELEVATIONS. GR-17 THE CONTRACTOR SHALL VERIFY ALL OPENING SIZES AND LOCATIONS WITH OTHER DISCIPLINES.

THE DRAWINGS DO NOT SHOW ALL OPENINGS REQUIRED. ADDITIONAL OPENINGS, BLOCKOUTS AND SLEEVES MAY BE REQUIRED BY OTHER DISCIPLINES AND SHALL BE CONSTRUCTED USING THE TYPICAL DETAILS AND/OR THE CRITERIA INDICATED ON THE DRAWINGS. OPENINGS REQUIRED BUT NOT SHOWN ON THE STRUCTURAL DRAWINGS MUST BE APPROVED BY THE SER.

GR-18 ELEVATIONS INDICATED ON STRUCTURAL DRAWINGS ARE BASED ON A PROJECT DATUM INDICATED

ON THE ARCHITECTURAL DRAWINGS. GR-19 SEE ARCHITECTURAL, CIVIL, MEP, AND VERTICAL TRANSPORTATION CONTRACT DOCUMENTS FOR

ADDITIONAL INFORMATION RELATING TO THE COORDINATION OF STRUCTURAL COMPONENTS INCLUDING, BUT NOT LIMITED TO:

ARCHITECTURAL: PLAN DIMENSIONS AND PROJECT DATUM SLAB EDGE DIMENSIONS FINISH ELEVATIONS WATERPROOFING AND DAMP-PROOFING DETAILS RAMP GEOMETRY, PITS, SLAB SLOPES AND DEPRESSIONS EMBEDMENTS, INSERTS, BLOCKOUTS, ETC. EXACT OPENING SIZES FOR PIPES, DUCTS, ETC CONCRETE FINISHES AND TOPPING SLABS CONCRETE CURBS AND HOUSEKEEPING PADS INTERIOR NON-STRUCTURAL MASONRY PARTITIONS FIRE RATINGS METAL PAN STAIRS AND SUPPORTS OPERABLE PARTITIONS

PIPE AND DUCT SIZES FOR OPENING AND SLEEVE COORDINATION FLOOR DRAINS UNDERFLOOR AND PERIMETER DRAINAGE SYSTEMS **EQUIPMENT CURBS** CONDUITS AND EMBEDMENTS IN WALLS AND SLABS

CD CODES AND DESIGN CRITERIA

CD-1 PERFORM ALL CONSTRUCTION IN CONFORMANCE WITH THE BUILDING AND DESIGN CODES REFERENCED WITHIN THESE DOCUMENTS. THE PROJECT DOCUMENTS REFER TO THE FOLLOWING CODES AND STANDARDS, UON: INTERNATIONAL BUILDING CODE, 2024 EDITION 5

STRUCTURAL LOADINGS: "MINIMUM DESIGN LOADS AND ASSOCIATED CRITERIA FOR BUILDINGS AND OTHER STRUCTURES" ASCE/SEI 7-16

STRUCTURAL CONCRETE: "BUILDING CODE REQUIREMENTS FOR STRUCTURAL CONCRETE" THE AMERICAN CONCRETE INSTITUTE (ACI 318-19)

MASONRY:
"BUILDING CODE REQUIREMENTS FOR MASONRY STRUCTURES"

"SPECIFICATION FOR MASONRY STRUCTURES" THE AMERICAN CONCRETE INSTITUTE (TMS 602-16)

THE AMERICAN CONCRETE INSTITUTE (TMS 402-16)

"SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS". (AISC 360-16) CONFORMING TO THE PROVISIONS OF LOAD RESISTANCE FACTOR DESIGN, BY THE AMERICAN INSTITUTE OF STEEL

CD-2 SUPERIMPOSED DEAD LOADS (SERVICE LEVEL):

CONSTRUCTION (AISC-LRFD)

SEE DESIGN LOAD DIAGRAMS ON SHEET S-010 - S-011 FOR LOCATIONS AND EXTENT OF SUPERIMPOSED DEAD LOADS.

CD-3 OCCUPANCY OR RISK CATEGORY: III

SNOW DRIFTING PER CODE

CD-9 SERVICEABILITY

CD-4 SNOW LOADS (SERVICE LEVEL): FLAT ROOF SNOW LOAD (Pf): GROUND SNOW LOAD (Pg) 20 PSF SNOW EXPOSURE FACTOR (Ce): SNOW LOAD IMPORTANCE FACTOR (Is): 1.25 THERMAL FACTOR (Ct):

CD-5 WIND LOAD DESIGN DATA (STRENGTH LEVEL): MAIN WIND FORCE RESISTING SYSTEM BASIC WIND SPEED, V 116 MPH INTERNAL PRESSURE COEFFICIENT ± 0.18

CD-6 IN CASES WHERE THE CONTRACTOR DETERMINES THAT SUSPENDED OR FLOOR MOUNTED EQUIPMENT LOADS EXIST WHICH EXCEED DESIGN LOADS INDICATED ON CONTRACT DOCUMENTS. CONTRACTOR SHALL SUBMIT LOAD DATA TO DESIGN PROFESSIONALS FOR REVIEW PRIOR TO PROCEEDING WITH WORK.

CD-7 DISTRIBUTE THE MAXIMUM LOAD HUNG FROM ANY STRUCTURAL MEMBER FOR DUCTWORK, PIPING ETC OVER THE MEMBER'S TRIBUTARY AREA IN A WAY THAT THE MEP DESIGN SUPERIMPOSED DEAD LOADS LISTED IN CONTRACT DOCUMENTS ARE NOT EXCEEDED. THE CONTRACTOR SHALL COORDINATE THE LOADS OF ALL TRADES AND PROVIDE ADDITIONAL SUPPORT OR DISTRIBUTION FRAMING AS REQUIRED TO ACHIEVE THE ALLOWABLE LOAD DISTRIBUTION.

CD-8 STRUCTURAL COMPONENTS ARE NOT DESIGNED FOR VIBRATING EQUIPMENT. MOUNT VIBRATING EQUIPMENT ON VIBRATION ISOLATORS.

LATERAL DRIFT DUE TO WIND LOADS IS LESS THAN OR EQUAL TO H/400 AT RECRUITING ROOM. CD-10 CONNECTIONS OF SYSTEMS DESIGNED BY CONTRACTOR'S ENGINEER SUCH AS, BUT NOT LIMITED TO, CLADDING, STAIRS, ELEVATORS, ESCALATORS, PRECAST, AND MEP LOADS ARE ASSUMED TO IMPOSE VERTICAL AND/OR HORIZONTAL LOADS ON THE BASE BUILDING STRUCTURAL MEMBERS WITHOUT GENERATING TORSION IN THE SUPPORTING STRUCTURAL MEMBERS. CONTRACTOR IS RESPONSIBLE FOR FURNISHING AND INSTALLING ALL SUPPLEMENTARY BRACING MEMBERS AS REQUIRED TO PREVENT TORSION ON THE BASE BUILDING STRUCTURE.

SU SUBMITTALS

316100 FOOTINGS

SU-1 THE CONTRACTOR SHALL PROVIDE THE REQUIRED SUBMITTALS FOR STRUCTURAL REVIEW AS OUTLINED IN THE SPECIFICATIONS. THIS INCLUDES BOTH ITEMS FULLY DESIGNED ON THE CONTRACT DOCUMENTS AND ITEMS LISTED AS DELEGATED DESIGN. ITEMS INCLUDE BUT ARE NOT LIMITED TO: 032000 CONCRETE REINFORCEMENT AND EMBEDDED ASSEMBLIES 033000 CAST-IN-PLACE CONCRETE 051200 STRUCTURAL STEEL

SU-2 SUBMIT LOADS IMPOSED ONTO BASE BUILDING STRUCTURE BY THE FOLLOWING CONTRACTOR DESIGNED SYSTEMS: EXTERIOR CLADDING SYSTEMS

WHERE CONTRACTOR LOADS IMPOSED DO NOT EXCEED AND/OR CONNECTION CONDITIONS DO NOT DIFFER FROM WHAT IS INDICATED IN THE STRUCTURAL DRAWINGS, SUBMIT FOR RECORD A LETTER SEALED AND SIGNED BY A PROFESSIONAL ENGINEER LICENSED IN THE STATEWHERE THE PROJECT IS LOCATED STATING THE FOLLOWING:

"THE CONTRACTOR DESIGNED SYSTEM HAS BEEN DESIGNED TO IMPOSE LOADS ON THE BASE BUILDING STRUCTURE THAT ARE WITHIN THE LOAD LIMITS AND AT THE LOCATIONS INDICATED ON THE STRUCTURAL DRAWINGS."

WHERE CONTRACTOR LOADS IMPOSED FOR THE ITEMS LISTED ABOVE EXCEED AND/OR CONNECTION CONDITIONS DIFFER FROM WHAT IS SHOWN IN THE STRUCTURAL DRAWINGS, SUBMIT FOR APPROVAL TO SER LOADS IMPOSED ON THE PRIMARY STRUCTURAL FRAME DUE TO THE DEAD, LIVE, AND WIND/SEISMIC LOADS INDICATED ON THE CONTRACT DOCUMENTS.

SUBMITTAL SHALL LIST THE DESIGN LOADS USED AND BE SEALED AND SIGNED BY A PROFESSIONAL ENGINEER LICENSED IN THE STATE WHERE THE PROJECT IS LOCATED. SUBMITTAL SHALL INCLUDE LOCATION, MAGNITUDE AND DIRECTION OF UNFACTORED IMPOSED LOADS, GRAPHICALLY REPRESENTED IN THEIR APPROPRIATE LOCATIONS ON A COPY OF THE CONTRACT DOCUMENT STRUCTURAL FRAMING PLANS OR ELEVATIONS AS APPROPRIATE. DETAIL REFERENCES IN THE CONNECTIONS APPLICABLE AT EACH LOCATION SHALL BE NOTED ON THE SUBMITTAL DRAWINGS.

FOR EXTERIOR WALL ASSEMBLIES, THE LOADS IMPOSED SUBMITTAL SHALL BE COMPREHENSIVE INDICATING THE LOADS IMPOSED ON THE BASE BUILDING STRUCTURE AND SHALL INCLUDE THE REACTIONS BASED ON THE ACTUAL LOADS OF THE ENTIRE ASSEMBLY, INCLUDING BUT NOT LIMITED TO GLAZING, CLADDING, METAL STUD BACKUP, AND MULLIONS.

FOR MEP SYSTEMS, THE LOADS IMPOSED SUBMITTAL SHALL BE COMPREHENSIVE INDICATING THE LOADS IMPOSED ON THE BASE BUILDING STRUCTURE AND SHALL INCLUDE THE REACTIONS BASED ON THE ACTUAL LOADS OF THE ENTIRE MECHANICAL, ELECTRICAL, PLUMBING, AND FIRE PROTECTION SYSTEM, INCLUDING BUT NOT LIMITED TO PIPING, DUCTS, ELECTRICAL RACEWAYS, AND EQUIPMENT

A SUBSTITUTION REQUEST MAY BE REQUIRED WHERE CONTRACTOR LOADS IMPOSED EXCEED AND/OR CONNECTION CONDITIONS DIFFER FROM THE BASIS OF DESIGN.

SU-3 THE SER'S REVIEW OF SUBMITTALS SHALL BE FOR GENERAL CONFORMANCE WITH THE DESIGN

SU-4 ALL SHOP DRAWINGS SHALL BE ORIGINAL DOCUMENTS AND NOT REPRODUCTIONS OF THESE CONTRACT DOCUMENTS.

INTENT. NO WORK SHALL BE STARTED WITHOUT SUCH REVIEW.

CM CONCRETE MATERIALS

CM-1 CONCRETE STRENGTH SHALL MEET THE FOLLOWING 28-DAY COMPRESSIVE STRENGTHS (f c), UON: CONCRETE ELEMENT EXPOSURE CATEGORY FOOTINGS 4.500 PSI / 28-DAY F2-S0-W0-C1 NON-SHRINK GROUT 8,000 PSI / 28-DAY INTERIOR SLAB ON GRADE **4,000** PSI / **28**-DAY **F0-S0-W0-C0** CONCRETE EARLY COMPRESSIVE STRENGTH REQUIREMENTS FOR CONSTRUCTION SHALL BE ESTABLISHED AND COORDINATED BY THE CONTRACTOR AND SUBMITTED TO THE SER FOR REVIEW.

CM-2 PROVIDE NORMALWEIGHT CONCRETE WITH CURED DENSITY OF 145 +/- 5 PCF, AND AGGREGATE CONFORMING TO ASTM C33, UON. WHERE INDICATED, PROVIDE LIGHTWEIGHT CONCRETE WITH CURED DENSITY OF 112+/-3 PCF AND AGGREGATE CONFORMING TO ASTM C330.

CM-3 THE USE OF CALCIUM CHLORIDE AND OTHER CHLORIDE CONTAINING AGENTS IS PROHIBITED. THE USE OF RECYCLED CONCRETE IS PROHIBITED. PLACEMENT WITHIN AND CONTACT BETWEEN ALUMINUM ITEMS, INCLUDING ALUMINUM CONDUIT, AND CONCRETE IS PROHIBITED.

CM-4 THE CONCRETE SLABS-ON-GRADE HAS BEEN DESIGNED FOR THE FINAL USE AND NOT FOR CONSTRUCTION CONSIDERATIONS. CONTRACTOR SHALL COORDINATE SLAB DESIGN WITH CONSTRUCTION NEEDS. THE SLAB

DESIGN INDICATED ON THESE DRAWINGS IS TO BE CONISDERED A MINIMUM. SUBMIT CHANGES TO THE SLAB DESIGN TO SER FOR REVIEW. CM-5 ALL CAST-IN-PLACE CONCRETE WILL EXPERIENCE DIFFERING VARIATIONS OF CRACKING. ANY ELEMENT EXPOSED TO DIRECT WEATHER AND/OR TEMPERATURE VARIATIONS DURING CONSTRUCTION OR IN THE FINAL

CONDITION IS TO BE TREATED AND REGULARLY MAINTAINED TO PREVENT PROPAGATION OF CRACKS AND

WATER PENETRATION. THE CONTRACTOR SHALL DEVELOP A REGULAR MAINTENANCE PROGRAM AND SUBMIT IT

CM-6 PRIOR TO PLACING CONCRETE IN ANY LOCATION, IT IS THE RESPONSIBILITY OF THE GENERAL CONTRACTOR TO HAVE THOROUGHLY CHECKED AND COORDINATED ALL DIMENSIONS, ELEVATIONS, OPENINGS, RECESSES, AND BLOCKOUTS SHOWN ON THE ARCHITECTURAL, STRUCTURAL, AND MECHANICAL/ELECTRICAL/PLUMBING DRAWINGS. IN THE EVENT ERRORS, CONFLICTS, OR OMISSIONS EXIST, IT SHALL BE THE CONTRACTOR'S

RE CONCRETE REINFORCEMENT

RE-1 ALL CONCRETE SHALL INCLUDE REINFORCEMENT. IF REINFORCEMENT IS NOT SPECIFICALLY INDICATED ON THE DRAWINGS VERIFY WITH THE SER.

RE-5 DOWELS SHALL MATCH SIZE AND SPACING OF MAIN REINFORCEMENT UON.

RE-2 REINFORCEMENT SHALL CONFORM TO THE FOLLOWING STANDARDS AND MATERIAL PROPERTIES UON:

RESPONSIBILITY TO CONTACT THE ARCHITECT OR SER FOR NECESSARY CORRECTIVE ACTION.

DEFORMED BARS: ASTM A615 GRADE 60 WELDABLE DEFORMED BARS: ASTM A706

RE-3 DETAIL REINFORCEMENT BASED ON THE PROJECT REQUIREMENTS, ACI-318 AND ACI-315, UON.

RE-4 WHERE A 90-DEG, 135 –DEG OR 180-DEG HOOK IS GRAPHICALLY INDICATED, PROVIDE CORRESPONDING ACI STANDARD HOOKS UON.

RE-6 PROVIDE CORNER BARS AT THE EXTERIOR FACE OF ALL WALL AND FOOTING CORNERS EQUAL TO HORIZONTAL

RE-7 REINFORCEMENT SHALL HAVE CONCRETE PROTECTION (CLEAR COVER) PER ACI 318 UNLESS OTHERWISE INDICATED ON THE DRAWINGS.

RE-8 LAP REINFORCEMENT ONLY AT LOCATIONS AS SPECIFICALLY DETAILED ON THE DRAWINGS EXCEPT REINFORCEMENT MARKED AS CONTINUOUS CAN BE SPLICED AT LOCATIONS DETERMINED BY CONTRACTOR USING TENSION LAP SPLICES (LTS). SEE LAP SPLICE AND EMBEDMENT SCHEDULE.

RE-9 UNLESS OTHERWISE NOTED ALL LAP SPLICES ARE TO BE TENSION LAP SPLICES PER LAP SPLICE AND EMBEDMENT

RE-10 ALL ACCESSORIES FOR SUPPORTING REINFORCING SHALL BE GALVANIZED OR HAVE PLASTIC COATED FEET.

SS STRUCTURAL STEEL

SS-1 STEEL MATERIALS SHALL CONFORM TO THE FOLLOWING MINIMUM REQUIREMENTS UNLESS OTHERWISE NOTED ON THE CONTRACT DOCUMENTS. SEE ADDITIONAL MATERIAL REQUIREMENTS RELATED TO MATERIAL TOUGHNESS BELOW: ASTM A6 ROLLED W SHAPES AND CHANNELS: ASTM A572 OR A992, MINIMUM YIELD STRENGTH 50 KSI MISCELLANEOUS ANGLES: ASTM A572 OR A529, MINIMUM YIELD STRENGTH 50 KSI UON

HOLLOW STRUCTURAL SECTIONS: ASTM A500 GRADE C, MINIMUM YIELD STRENGTH 50 KSI FOR RECTANGULAR HSS SS-2 CONNECTION MATERIAL SHALL CONFORM TO THE FOLLOWING MINIMUM REQUIREMENTS OR AS NEEDED FOR CONNECTION DESIGN:

ASTM A572 OR A529, MINIMUM YIELD STRENGTH 50 KSI UON PLATES: BOLTS: ASTM F3125 GRADES A325 AND F1852 ASTM A563 WASHERS: ASTM F436 ASTM F1554 GRADE 55 WITH WELDABILITY SUPPLEMENT S1 ANCHOR RODS:

WELD ELECTRODES: MINIMUM TENSILE STRENGTH 70 KSI AT 50 KSI STEEL MATERIALS

SS-3 FIELD MODIFICATION OF STRUCTURAL STEEL IS PROHIBITED WITHOUT PRIOR WRITTEN APPROVAL OF THE DESIGN PROFESSIONALS.

SC STRUCTURAL STEEL CONNECTIONS

SC-1 ALL STEEL DETAILS AND CONNECTIONS SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF "SPECIFICATION FOR STRUCTURAL STEEL BUILDINGS". AISC-LOAD AND RESISTANCE FACTOR DESIGN.

SC-2 ALL CONNECTIONS INDICATED ON STRUCTURAL DRAWINGS HAVE BEEN COMPLETELY DESIGNED.

SC-3 DETAILS INDICATED ON DRAWINGS DO NOT SHOW ERECTION AIDS. PROVIDE ERECTION AIDS AS REQUIRED AND REMOVE THEM AFTER WORK IS COMPLETE.

SC-4 ALTERNATE CONNECTIONS TO THOSE SHOWN ON DRAWINGS WILL BE CONSIDERED AS A SUBSTITUTION REQUEST. SEE PROJECT SPECIFICATIONS.

SC-5 ALL WELDING SHALL CONFORM TO THE REQUIREMENTS OF THE STRUCTURAL WELDING CODE, ANSI/AWS D1.1, LATEST EDITION. ALL WELD SIZES SHALL BE THE LARGER OF THE SIZE REQUIRED BY CONNECTION FORCES. THE MINIMUM SIZE PER ANSI/AWS D1.1. OR 3/16 INCH MINIMUM FILLET WELD UON. ANY WELD SIZES SHOWN ON THE DESIGN DRAWINGS ARE CONSIDERED EFFECTIVE WELD SIZES AND SHALL BE INCREASED IN ACCORDANCE WITH AWS AS REQUIRED BY GAPS OR SKEWS BETWEEN COMPONENTS.

SI SPECIAL INSPECTIONS

SI-1 THE FOLLOWING STRUCTURAL ITEMS REQUIRE SPECIAL TESTING AND/OR INSPECTIONS:

REFER TO SHEET S-003 AND S-004 FOR SPECIAL INSPECTION REQUIREMENTS.

SI-2 THE OWNER IS RESPONSIBLE FOR EMPLOYING ONE OR MORE SPECIAL INSPECTORS TO PERFORM INSPECTIONS DURING CONSTRUCTION, BASED ON THE REQUIREMENTS OF ONE OR MORE DESIGN

SI-3 THE CONTRACTOR SHALL REQUEST SPECIAL INSPECTION OF THE ITEMS LISTED ABOVE PRIOR TO THOSE ITEMS BECOMING INACCESSIBLE AND UNOBSERVABLE DUE TO PROGRESSION OF WORK. CONTRACTOR SHALL PROVIDE SAFE ACCESS TO THE JOB SITE AND ITEMS TO BE INSPECTED. SAFE ACCESS INCLUDES BUT IS NOT LIMITED TO LADDERS, SCAFFOLDING AND/OR CONTRACTOR OPERATED LIFTS AS REQUIRED FOR SITE OBSERVATION.

SI-4 SPECIAL INSPECTOR SHALL PROVIDE BI-WEEKLY SPECIAL INSPECTION REPORTS AND SHALL DISTRIBUTE THESE REPORTS TO THE BUILDING OFFICIAL, OWNER, CONTRACTOR, ARCHITECT, STRUCTURAL ENGINEER OF RECORD, AND MECHANICAL/ELECTRICAL/PLUMBING ENGINEER OF RECORD. SPECIAL INSPECTION REPORTING SHALL BE IN ACCORDANCE WITH SECTION 1704.2.4 OF THE 2021 IBC.

SI-5 ALL DISCREPANCIES NOTED DURING INSPECTIONS SHALL BE BROUGHT TO THE IMMEDIATE ATTENTION OF THE CONTRACTOR. IF LEFT UNCORRECTED, THESE DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF THE APPROPRIATE DESIGN PROFESSIONALS AND/OR BUILDING OFFICIAL. THE INSPECTOR IS NOT AUTHORIZED TO APPROVE DEVIATIONS FROM THE CONTRACT DRAWINGS.

SI-6 THE CONTRACT STRUCTURAL DRAWINGS AND SPECIFICATIONS REPRESENT THE FINISHED STRUCTURE. AND, EXCEPT WHERE SPECIFICALLY SHOWN, DO NOT INDICATE THE METHOD OR MEANS OF CONSTRUCTION. THE CONTRACTOR SHALL SUPERVISE AND DIRECT THE WORK AND SHALL BE SOLELY RESPONSIBLE FOR ALL CONSTRUCTION MEANS, METHODS, PROCEDURES, TECHNIQUES, AND SEQUENCES.

SI-7 THE ENGINEER SHALL NOT HAVE CONTROL NOR CHARGE OF, AND SHALL NOT BE RESPONSIBLE FOR,

CONSTRUCTION MEANS, METHODS, TECHNIQUES, SEQUENCES, OR PROCEDURES, FOR SAFETY

PRECAUTIONS AND PROGRAMS IN CONNECTION WITH THE WORK, FOR THE ACTS OR OMISSION OF THE

CONTRACTOR, SUBCONTRACTOR, OR ANY OTHER PERSONS PERFORMING ANY OF THE WORK, OR FOR THE

FAILURE OF ANY OF THEM TO CARRY OUT THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS. SI-8 PERIODIC SITE OBSERVATION BY FIELD REPRESENTATIVES OF THORNTON TOMASETTI AND PMA ENGINEERING IS SOLELY FOR THE PURPOSE OF DETERMINING IF THE WORK OF THE CONTRACTOR IS PROCEEDING IN GENERAL ACCORDANCE WITH THE STRUCTURAL CONTRACT DOCUMENTS. THIS LIMITED SITE OBSERVATION SHOULD NOT BE CONSTRUED AS EXHAUSTIVE OR CONTINUOUS TO CHECK THE QUALITY OR QUANTITY OF THE WORK, BUT RATHER PERIODIC IN AN EFFORT TO GUARD THE OWNER

AGAINST DEFECTS OR DEFICIENCIES IN THE WORK OF THE CONTRACTOR.

AC ARCHITECTURAL CLADDING

AC-1 TYPICAL DETAILS INDICATE GENERAL CRITERIA FOR ASSUMED CONNECTIONS OF ARCHITECTURAL CLADDING TO BASE BUILDING STRUCTURE. PROVIDE DESIGNS THAT MEET INDICATED CRITERIA AND CONFORM TO LISTED CODES AND STANDARDS. REFER TO SUBMITTALS SECTION IN THESE GENERAL NOTES FOR ADDITIONAL REQUIREMENTS.

PA POST-INSTALLED ANCHORS

HILTI KH-EZ

PA-1 ADHESIVE ANCHOR SYSTEMS USED FOR DESIGN:

OVERHEAD AND/OR CONSTANT TENSION ADHESIVE ANCHOR INSTALLATIONS NOT SHOWN ON THE DRAWINGS SHALL NOT BE PERMITTED UNLESS EACH CONDITION IS REVIEWED AND APPROVED IN WRITING BY THE SER.

PA-2 PROOF TESTING OF ADHESIVE ANCHORS SHALL BE PERFORMED IN ACCORDANCE WITH THE PROJECT SPECIFICATIONS. UNLESS NOTED OTHERWISE, ADHESIVE ANCHOR PROOF TENSION LOADS SHALL BE PER THE ADHESIVE ANCHOR PROOF SCHEDULES.

PA-3 PROOF TESTING OF EXPANSION ANCHORS SHALL BE PERFORMED IN ACCORDANCE WITH THE PROJECT SPECIFICATIONS. UNLESS NOTED OTHERWISE, EXPANSION ANCHOR PROOF TORQUE LOADS SHALL BE PER THE EXPANSION ANCHOR PROOF SCHEDULES.

PA-4 FIELD DRILLED THREADED SCREW ANCHOR SYSTEMS USED FOR DESIGN:

PA-5 ALTERNATIVE SYSTEM EQUIVALENT TO OR EXCEEDING THE PROPERTIES OF THE SYSTEMS ABOVE WILL BE CONSIDERED AS A SUBSTITUTION REQUEST. SEE PROJECT SPECIFICATIONS.

PA-6 INSTALL ANCHORS TO MEET THE REQUIREMENTS INDICATED IN THE CONTRACT DOCUMENTS AND THE CURRENT MANUFACTURER'S PUBLISHED INSTALLATION INSTRUCTIONS (MPII).

PA-7 LOCATE, BY NON-DESTRUCTIVE MEANS, AND AVOID ALL EXISTING REINFORCEMENT PRIOR TO INSTALLATION OF ANCHORS. IF EXISTING REINFORCING LAYOUT PROHIBITS THE INSTALLATION OF ANCHORS AS INDICATED ON THE DRAWINGS, THE CONTRACTOR SHALL IMMEDIATELY NOTIFY THE DESIGN PROFESSIONALS.

PA-8 INSTALL ANCHORS IN SOLID MASONRY OR IN HOLLOW MASONRY THAT HAS BEEN GROUTED SOLID AT LEAST ONE COURSE ABOVE TO ONE COURSE BELOW THE ANCHOR, UON.

SI SPECIAL INSPECTIONS

SI-1 THE STRUCTURAL ITEMS LISTED IN THE INSPECTION TABLES ON SHEET S-002 REQUIRE SPECIAL

PA-9 SEE PROJECT SPECIFICATIONS FOR POST-INSTALLED ANCHOR INSPECTION REQUIREMENTS.

SI-2 SPECIAL INSPECTIONS TO BE PERFORMED IN ACCORDANCE WITH THE IBC 2021 BUILDING CODE.

SI-3 CONTRACTOR TO COORDINATE ALL CONSTRUCTION ACTIVITY WITH THE SELECTED SPECIAL INSPECTION COMPANY(S) TO ALLOW ADEQUATE NOTIFICATION OF IMPENDING CONSTRUCTION ACTIVITY. UON, 24

HOURS NOTICE SHOULD BE GIVEN AT A MINIMUM.

SI-4 THE SPECIAL INSPECTOR SHALL BE EMPLOYED BY THE OWNER AND NOT BY THE CONTRACTOR OR ANY OTHER PERSON RESPONSIBLE FOR THE WORK.

SI-5 THE SPECIAL INSPECTOR SHALL BE A QUALIFED (LICENSED) PERSON WHO SHALL PROVDE WRITTEN DOCUMENTATION TO THE BUILDING OFFICIAL DEMONSTRATING HIS OR HER COMPETENCE AND RELEVANT TRAINING OR EXPERIENCE TO THE SATISFACTION OF THE BUILDING OFFICIAL. EXPERIENCE SHALL BE FOR SPECIAL INSPECTIONS OF THE PARTICULAR TYPE OF CONSTRUCTION OR OPERATION REQUIRING SPECIAL INSPECTION.

SI-6 DISCREPANCY LOGS ARE TO BE MAINTAINED AND PROVIDED TO OWNER, ARCHITECT, ENGINEER, AND CONTRACTOR. ALL DISCREPANCIES SHOULD BE IMMEDIATELY BE BROUGHT TO THE CONTRACTOR AND

SI-7 REPORTS SHOULD BE SUBMITTED IN A TIMELY MANNER, NO GREATER THAN 2 WEEK INTERVALS. DISCREPANCIES MUST BE COMMUNICATED IMMEDIATELY.

SI-8 DISCREPANCY ITEMS FOUND BY THE SPECIAL INSPECTOR(S) AND BROUGHT INTO COMPLIANCE WITH THE CONTRACT DOCUMENTS IN THE FIELD SHOULD BE NOTED IN THE DAILY REPORTS. THIS INCLUDES, BUT IS NOT LIMITED TO, INCORRECT REINFORCING SIZES OR INCORRECT SPACING OF REINFORCING. MODIFICATIONS OUTSIDE THE DIRECTION OF THE CONTRACT DOCUMENTS WILL REQUIRE A DISCREPANCY REPORT.

SI-9 PERIODIC OBSERVATIONS PERFORMED BY THE ENGINEER OF RECORD AND THEIR REPRESENTATIVES DO NOT REPLACE THE REQUIREMENT FOR SPECIAL INSPECTIONS.

BY THE SELECTED SPECIAL INSPECTION COMPANY.

SI-10 REGARDING STEEL INSPECTIONS, QUALITY CONTROL (QC) SHALL BE PERFORMED BY THE FABRICATOR'S OR ERECTOR'S QUALITY CONTROL INSPECTOR AND QUALITY ASSURANCE (QA) SHALL BE PERFORMED

SI-11 FOR MORE INFORMATION, REFER TO THE TT SPECIFICATION SECTIONS FOR THE INDIVIDUAL STRUCTURAL MATERIALS AS LISTED IN THE INSPECTION TABLES. ALSO REFER TO SPECIFICATION SECTION 014500 - STUCTURAL TESTING AND INSPECTIONS FOR FURTHER DETAIL REGARDING STRUCTURAL TESTING AND SPECIAL INSPECTIONS.







OTHER PROJECT DRAWINGS NOT

DIRECTLY BEARING THIS SEAL.







GENERAL NOTES

REFERENCE IBC 2024 TABLE 1705.3

a. SPECIFIC REQUIREMENTS FOR SPECIAL INSPECTION SHALL BE INCLUDED IN THE RESEARCH REPORT FOR THE ANCHOR ISSUED BY AN APPROVED SOURCE IN ACCORDANCE WITH 17.8.2 IN ACI 318 OR OTHER QUALIFICATION PROCEDURES. WHERE SPECIFIC REQUIREMENTS ARE NOT PROVIDED, SPECIAL INSPECTION REQUIREMENTS SHALL BE SPECIFIED BY THE REGISTERED DESIGN PROFESSIONAL AND SHALL BE APPROVED BY THE BUILDING OFFICIAL PRIOR TO THE

INSPECTION TASKS DURING TO WELDING	QUALITY CONTROL	QUALITY ASSURANCE	CODE STANDARD(S)	TT SPECIFICATION
	QOVERNOOT	Q0/12/11 / (000) d d 1/0	CODE STANDARD(S)	
CONTROL AND HANDLING OF WELDING CONSUMABLES: PACKAGING	0	0	-	051200
ONTROL AND HANDLING OF WELDING CONSUMABLES: XPOSURE CONTROL	0	0	-	051200
IO WELDING OVER CRACKED TACK WELDS	0	0	-	-
ENVIRONMENTAL CONDITIONS: WIND SPEED WITHIN LIMITS	0	0	-	051200
ENVIRONMENTAL CONDITIONS: PRECIPITATION AND EMPERATURE	0	0	-	051200
VPS FOLLOWED: SETTINGS ON WELDING EQUIPMENT	0	0	-	051200
VPS FOLLOWED: TRAVEL SPEED	0	0	-	051200
VPS FOLLOWED: SELECTED WELDING MATERIALS	0	0	-	051200
VPS FOLLOWED: SHIELDING GAS TYPE/FLOW RATE	0	0	-	051200
VPS FOLLOWED: PREHEAT APPLIED	0	0	-	051200
VPS FOLLOWED: INTERPASS TEMPERATURE MAINTAINED (MIN./MAX.)	0	0	-	051200
VPS FOLLOWED: PROPER POSITION (F, V, H, OH)	0	0	-	051200
VELDING TECHNIQUES: INTERPASS AND FINAL CLEANING	0	0	-	051200
ELDING TECHNIQUES: EACH PASS WITHIN PROFILE LIMITATIONS	0	0	-	051200
EQUIREMENTS	0	0	-	051200
PLACEMENT AND INSTALLATION OF STEEL HEADED STUD ANCHORS	P	P	-	051200

REFERENCE AISC 360-16 TABLE N5.4-2

O - OBSERVE THESE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS. P - PERFORM THESE TASKS FOR EACH WELDED JOINT OF MEMBER

INSPECTION TASKS AFTER WELDING INSPECTION TASKS AFTER WELDING QUALITY CONTROL QUALITY ASSURANCE CODE STANDARD(S) TT SPECIFICATION											
INSPECTION TASKS AFTER WELDING	QUALITY CONTROL	QUALITY ASSURANCE	CODE STANDARD(S)	TT SPECIFICATION							
WELDS CLEANED	0	0	-	051200							
SIZE, LENGTH AND LOCATION OF WELDS	Р	Р	-	051200							
WELDS MEET VISUAL ACCEPTANCE CRITERIA: CRACK PROHIBITION	Р	Р	-	051200							
WELDS MEET VISUAL ACCEPTANCE CRITERIA: WELD/BASE-METAL FUSION	Р	Р	-	051200							
WELDS MEET VISUAL ACCEPTANCE CRITERIA: CRATER CROSS SECTION	Р	Р	-	051200							
WELDS MEET VISUAL ACCEPTANCE CRITERIA: WELD PROFILES	Р	Р	-	051200							
NELDS MEET VISUAL ACCEPTANCE CRITERIA: WELD SIZE	Р	Р	-	051200							
NELDS MEET VISUAL ACCEPTANCE CRITERIA: UNDERCUT	Р	Р	-	051200							
NELDS MEET VISUAL ACCEPTANCE CRITERIA: POROSITY	Р	Р	-	051200							
ARC STRIKES	Р	Р	-	051200							
K-AREA 1	Р	Р	-	051200							
NELD ACCESS HOLES IN ROLLED HEAVY SHAPES AND BUILT-UP HEAVY SHAPES ²	Р	Р	-	051200							
BACKING REMOVED AND WELD TABS REMOVED (IF REQUIRED)	Р	Р	-	051200							
REPAIR ACTIVITIES	Р	Р	-	051200							
NO PROHIBITED WELDS HAVE BEEN ADDED WITHOUT APPROVAL OF THE EOR	0	0	-	051200							
OOCUMENT ACCEPTANCE OR REJECTION OF WELDED JOINT OR MEMBER	Р	Р	-	051200							
ION-DESTRUCTIVE TESTING OF COMPLETE AND PARTIAL JOINT PENETRATION WELDS. ALL LAWS SHOULD BE REPAIRED AND RE-TESTED	Р	Р	-	051200							
NSPECTION OF POST BASE WELDS FOR CANTILEVERED RAILING SYSTEMS (IBC 2021 ECTION 1705.2.1)	Р	P	-	-							

REFERENCE AISC 360-16 TABLE N5.4-3

- 1 WHEN WELDING OF DOUBLER PLATES, CONTINUITY PLATES OR STIFFENERS HAS BEEN PERFORMED IN THE K-AREA, VISUALLY INSPECT THE WEB K-AREA FOR CRACKS WITHIN 3 IN. (75 MM) THE WELD
- 2 AFTER ROLLED HEAVY SHAPES (SEE AISC 360 SECTION A3.1C) AND BUILT-UP HEAVY SHAPES (SEE AISC 360 SECTION A3.1D) ARE WELDED, VISUALLY INSPECT THE WELD ACCESS HOLE FOR CRACKS
- O OBSERVE THESE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS.
- P PERFORM THESE TASKS FOR EACH WELDED JOINT OF MEMBER

INSPECTION TASKS PRIOR TO BOLTING											
INSPECTION TASKS PRIOR TO BOLTING	QUALITY CONTROL	QUALITY ASSURANCE	CODE STANDARD(S)	TT SPECIFICATION							
MANUFACTURER'S CERTIFICATIONS AVAILABLE FOR FASTENER MATERIALS	0	Р	-	051200							
FASTENERS MARKED IN ACCORDANCE WITH ASTM REQUIREMENTS	0	0	-	-							
CONNECTING ELEMENTS, INCLUDING THE APPROPRIATE FAYING SURFACE CONDITION AND HOLE PREPARATION, IF SPECIFIED, MEET APPLICABLE REQUIREMENTS	0	0	-	051200							
PRE-INSTALLATION VERIFICATION TESTING BY INSTALLATION PERSONNEL OBSERVED AND DOCUMENTED FOR FASTENER ASSEMBLIES AND METHODS USED	Р	0	-	051200							
PROTECTED STORAGE PROVIDED FOR BOLTS, NUTS, WASHERS AND DTHER FASTENER COMPONENTS	0	0	-	051200							

REFERENCE AISC 360-16 TABLE N5.6-1

O - OBSERVE THESE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS.

P - PERFORM THESE TASKS FOR EACH BOLTED CONNECTION

INSPECT	ION TASKS DUR	ING BOLTING		
INSPECTION TASKS DURING BOLTING	QUALITY CONTROL	QUALITY ASSURANCE	CODE STANDARD(S)	TT SPECIFICATION
FASTENER ASSEMBLIES PLACED IN ALL HOLES AND WASHERS ARE POSITIONED AS REQUIRED	0	0	-	051200
JOINT BROUGHT TO THE SNUG-TIGHT CONDITION PRIOR TO THE PRETENSIONING OPERATION	0	0	-	051200
FASTENER COMPONENT NOT TURNED BY THE WRENCH PREVENTED FROM ROTATING	0	0	-	051200
FASTENERS ARE PRETENSIONED IN ACCORDANCE WITH THE RCSC SPECIFICATION, PROGRESSING SYSTEMATICALLY FROM THE MOST RIGID POINT TOWARD THE FREE EDGES	0	0	-	051200

REFERENCE AISC 360-16 TABLE N5.6-2

O - OBSERVE THESE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS.

P - PERFORM THESE TASKS FOR EACH BOLTED CONNECTION

INSPECTION AFTER BOLTING										
INSPECTION TASKS AFTER BOLTING	QUALITY CONTROL	QUALITY ASSURANCE	CODE STANDARD(S)	TT SPECIFICATION						
DOCUMENT ACCEPTANCE OR REJECTION OF BOLTED CONNECTIONS	Р	Р	-	051200						

O - OBSERVE THESE ITEMS ON A RANDOM BASIS. OPERATIONS NEED NOT BE DELAYED PENDING THESE INSPECTIONS.

P - PERFORM THESE TASKS FOR EACH BOLTED CONNECTION

		REQUIRED VERIFICATION AND INSE	PECTION (JF STEE	L CONSTRUCTION	
		VERIFICATION AND INSPECTION	CONTINUOUS	PERIODIC	REFERENCED STANDARD	CBC REFERENCI
1. 1	MATE	ERIAL VERIFICATION OF HIGH-STRENGTH BOLTS, NUTS AND WASHERS:				
	Α.	IDENTIFICATION MARKINGS TO CONFORM TO ASTM STANDARDS SPECIFIED IN THE APPROVED CONSTRUCTION DOCUMENTS.	-	Х	AISC 360, SECTION A3.3 AND APPLICABLE ASTM MATERIAL STANDARDS	_
	В.	MANUFACTURER'S CERTIFICATE OF COMPLIANCE REQUIRED.	_	Х	_	_
2. I	INSP	ECTION OF HIGH-STRENGTH BOLTING:		<u>l</u>	1	l
	A.	SNUG-TIGHT JOINTS	_	Х		
	В.	PRETENSIONED AND SLIP-CRITICAL JOINTS USING TURN-OF-NUT WITH MATCHMARKING, TWIST-OFF BOLT OR DIRECT TENSION INDICATOR METHODS OF INSTALLATION.	Х	_	AISC 360, SECTION M2.5	_
3. 1	MATE	ERIAL VERIFICATION OF STRUCTURAL STEEL AND COLD-FORMED STEEL DECK:		l		l
	A.	FOR STRUCTURAL STEEL, IDENTIFICATION MARKINGS TO CONFORM TO AISC 360.	_	Х	AISC 360, SECTION A3.1H	2203.1
	В.	FOR OTHER STEEL, IDENTIFICATION MARKINGS TO CONFORM TO ASTM STANDARDS SPECIFIED IN THE APPROVED CONSTRUCTION DOCUMENTS.	_	х	APPLICABLE ASTM MATERIAL STANDARDS	_
	C.	MANUFACTURER'S CERTIFIED MILL TEST REPORTS.	_	_	ASTM A 6 OR ASTM A 568	
4. I	MATE	ERIAL VERIFICATION OF WELD FILLER MATERIALS:			•	
	A.	IDENTIFICATION MARKINGS TO CONFORM TO AWS SPECIFICATION IN THE APPROVED CONSTRUCTION DOCUMENTS.	_	_	AISC 360, SECTION A3.5 AND APPLICABLE AWS A5 DOCUMENTS	_
	В.	MANUFACTURER'S CERTIFICATE OF COMPLIANCE REQUIRED.	_	Х	_	_
		ECTION OF STEEL FRAME JOINT DETAILS FOR COMPLIANCE WITH ROVED CONSTRUCTION DOCUMENTS:	_	Х		
	A.	DETAILS SUCH AS BRACING AND STIFFENING.	_	Х] –	1705.2.1
	B.	MEMBER LOCATIONS.	_	Х		
	C.	APPLICATION OF JOINT DETAILS AT EACH CONNECTION.	_	Х		

	AR GRADE VARIES						DE	VE	ELO	PN	DEVELOPMENT LENGTH SCHEDULE (INCHES)																					SEE N	10TE
		841811841	IM DAD										TEN	NSIC	N												CON	/IPR	ESS	NOIS	Ī		
DAD	BAR GRADE	MINIMUM BAR SPACING (INCHES) [MAX(1",db) + db] NOTE 2					NOTE	D AS Lo	ON DR	AWING	3						NOTED	AS Ldh	ON DR	AWINGS)						NOTED	AS Ldc	ON DR	AWINGS	;		
BAR				1 (FSI)									f'c (PSI)																				
SIZE	(KSI)			3000	4000	2000	0009	2000	8000	0006	10,000	11,000	12,000	3000	4000	2000	0009	2000	8000	0006	10,000	11,000	12,000	3000	4000	2000	0009	7000	8000	0006	10,000	11,000	
		TENSION	COMPRESSION	1																													
#4	60	1 1/2	2	22	19	17	16	15	14	13	12	12	11	6	6	6	6	6	6	6	6	6	6	11	10	9	8	8	8	8	8	8	
#5	60	1 1/4	1 7/8	28	24	22	20	18	17	16	15	15	14	8	8	8	7	7	7	7	7	7	7	14	12	11	10	9	9	8	8	8	
#6	60	1 1/2	2 1/4	33	29	26	24	22	21	19	18	18	17	13	12	11	10	9	8	8	8	7	7	17	15	13	12	11	11	10	9	9	
#7	60	1 3/4	2 5/8	58	50	45	41	38	36	34	32	31	29	17	15	13	12	11	10	10	9	9	9	20	17	15	14	13	12	12	11	11	
#8	60	2	3	66	57	51	47	44	41	38	36	35	33	20	18	16	15	14	13	12	11	11	10	22	19	17	16	15	14	13	12	12	
#9	60	2 1/8	3 1/5	75	65	58	53	49	46	43	41	39	38	24	21	19	17	16	15	14	14	13	12	25	22	20	18	17	16	15	14	13	
#10	60	2 1/4	3 2/5	84	73	65	60	55	52	49	46	44	42	29	25	23	21	19	18	17	16	15	15	28	25	22	20	19	18	17	16	15	
#11	60	2 2/5	3 3/5	93	81	72	66	61	57	54	51	49	47	34	29	26	24	22	21	20	19	18	17	31	27	24	22	21	19	18	17	17	

DEVELOPMENT LENGTH SCHEDULE NOTES:

1. WHERE MORE THAN 12 INCHES OF FRESH CONCRETE IS CAST BELOW THE DEVELOPMENT LENGTH, MULTIPLY Ld BY 1.3.

SEISMIC DESIGN DATA:

SEISMIC DESIGN CATEGORY

SITE CLASS

2. WHERE STIRRUPS OR TIES ARE NOT PRESENT THROUGHOUT Ld, MINIMUM BAR SPACING MUST BE INCREASED TO [MAX(1", db) + 2db] FOR SCHEDULED VALUES TO BE APPLICABLE.

3. FOR HOOKED BARS SPACED MORE THAN 6 BAR DIAMETERS, OR WHEN RATIO OF TOTAL CROSS-SECTIONAL AREA OF STIRRUPS CONFINING HOOKED BARS TO TOTAL CROSS-SECTIONAL AREA OF HOOKED BARS BEING DEVELOPED IS MORE THAN 0.4, Ldh MAY BE REDUCED BY MULTIPLYING BY 0.625.

** WHERE MORE THAN 12" OF FRESH CONCRETE IS CAST BELOW THE SPLICE LOCATION, MULTIPLY LTS BY 1.3.

4. FOR HOOKED BARS ANCHORED WITHIN A COLUMN CORE WITH SIDE COVER MORE THAN 2.5 INCHES OR IN OTHER MEMBERS WITH SIDE COVER MORE THAN 6 AR DIAMETERS, Ldh MAY REDUCED BY MULTIPLYING BY 0.8.

LAP SPLICE NOTES:

1. TABULATED VALUES ARE PER ACI 318-19 REQUIREMENTS FOR NORMALWEIGHT CONCRETE. THE VALUES ON THIS SHEET DO NOT APPLY TO LIGHTWEIGHT CONCRETE

2. SEE TYPICAL DETAILS FOR CLEAR COVER

O SECOND BAR PLACED OR SPLICE BAR

4. WHERE ACTUAL CONDITIONS DIFFER FROM THE CLEAR COVER SHOWN ON THE TYPICAL DETAILS OR DIFFER FROM PROVIDED SCHEDULED BAR SIZE MINIMUM SPACING AND/OR fc, LENGTHS SHALL BE ADJUSTED ONLY WITH THE APPROVAL OF THE STRUCTURAL ENGINEER OF RECORD.

5. TABULATED VALUES ARE FOR NON-EPOXY COATED GRADE 60 REINFORCEMENT IN NORMALWEIGHT CONCRETE

FOR EPOXY COATED REINFORCEMENT: MULTIPLY Ld BY 1.5

MULTIPLY Ldh BY 1.2 Ldc IS NOT AFFECTED MULTIPLY LTS BY 1.3 FOR "TOP BARS" MULTIPLY LTS BY 1.5 FOR ALL OTHER REINFORCEMENT

6. WHERE BARS OF DIFFERENT SIZES ARE LAP SPLICED IN TENSION, THE TENSION LAP SPLICE LENGTH (LTS) SHALL BE THE LARGER OF THE TENSION DEVELOPMENT LENGTH (Ld) OF THE LARGER BAR AND THE TENSION LAP SPLICE LENGTH OF THE SMALLER BAR.

7. WHERE BARS OF DIFFERENT SIZES ARE LAP SPLICED IN COMPRESSION, THE COMPRESSION LAP LENGTH (LCS) SHALL BE THE LARGER OF THE COMPRESSION DEVELOPMENT LENGTH (Ldc) OF THE LARGER BAR OR THE COMPRESSION LAP SPLICE LENGTH OF THE SMALLER BAR.

8. "TOP BARS" ARE DEFINED AS HORIZONTAL REINFORCEMENT PLACED SUCH THAT MORE THAN 12 INCHES OF FRESH CONCRETE IS CAST BELOW THE DEVELOPMENT LENGTH OR SPLICE "OTHER BARS" ARE ALL BARS FOR WHICH THIS DOES NOT APPLY

	AR GRADE VARIES	SLAB/SLAB-ON-GRADE REINFORCEMENT LAP SPLICE LENGTH SCHEDULE (INCHES) SEE NOTE 5											
BAR	BAR GRADE	MINIMUM BAR	TENSION (LTS)**										
SIZE	(KSI)	SPACING (INCHES)	f'c = 3 KSI	f'c = 4 KSI	f'c = 5 KSI	f'c = 6 KSI	f'c = 7 KSI	f'c = 8 KSI					
#4	60	5 1/2	22	19	17	16	15	14					
#5	60	5 3/8	28	24	22	20	18	17					
40	00	E 1/A	22	20	26	24	22	21					


CAST-IN-PLACE NONPRESTRESSED CONCRETE **COVER SCHEDULE (ACI 318)**


		,	
CONCRETE EXPOSURE	MEMBER	BAR SIZE	CLEAR COVER (INCHES)
CAST AGAINST AND PERMANENTLY IN CONTACT WITH GROUND	ALL	ALL	3
EXPOSED TO WEATHER		#6 THROUGH #18 BARS	2
OR IN CONTACT WITH GROUND	ALL	#5 BAR, W31 OR D31 WIRE, AND SMALLER	1 1/2
	SLAB, JOISTS,	#14 AND #18 BARS	1 1/2
NOT EXPOSED TO	AND WALLS	#11 BAR AND SMALLER	3/4
WEATHER OR IN CONTACT WITH GROUND	BEAMS, COLUMNS, PEDESTALS, AND TENSION TIES	PRIMARY REINFORCEMENT, STIRRUPS, TIES, SPIRALS, AND HOOPS	1 1/2











SOA 25042 INSPECTIONS

HSS6X4X1/4 (FLAT) ROOF -

NEW 1/2" PLATE BTWN EXIST -HSS4X4 AND NEW HSS6X4 AT

OPERABLE DOOR RE: ARCH

EXIST HSS4X4 -

FRAME TO ROOF FRAME

HSS4X4X1/4 VERT EA

EXISTING ROOF FRAME

THE PROFESSIONAL ARCHITECT'S
SEAL ON THIS DRAWING HAS
BEEN AFFIXED IN ACCORDANCE
WITH THE REQUIREMENTS OF
CHAPTER 327, RSMO. IN AFFIXING
THIS SEAL, THE ARCHITECT

TAKES RESPONSIBILITY FOR THE WORK SHOWN ON THIS DRAWING ONLY, AND HEREBY DISCLAIMS ANY AND ALL RESPONSIBILITY FOR OTHER PROJECT DRAWINGS NOT DIRECTLY BEARING THIS SEAL.

ISSUE FOR BID
10/02/2025

ADD-01 10/29/2025

 GRADE BEAM REINFORCEMENT PER PLAN

GRADE BEAM REINFORCEMENT — PER PLAN


BACKFILL OVER PIPE PER CIVIL

STORM WATER LINE IN FIELD PRIOR TO POURING FOUNDATION

VERIFY LOCATION AND DEPTH OF

NOTES

1. APPLY DETAIL AS REQUIRED DEPENDING
ON ELEVATION OF STORM WATER LINE.





RECRUITMENT ROOM ISO VIEW

5 SCALE: 34" = 1-0"

STEPPED FOOTING DETAIL
NOT TO SCALE

TO STEPPED FOOTING DETAIL
NOT TO SCALE

STEPPED FOOTING DETAIL
NOT TO SCALE

1" CLR EA SIDE

#----

EXISTING CMU WALL TO REMAIN

SEE NOTE 1.

L8X8X1/2 FRAME AT OPENING PERIMETER.

GROUT BETWEEN FRAME AND MASONRY

 DUCTS OPENING. COORDINATE EXTENTS AND LOCATION WITH MECHANICAL LAYOUT. FILL GAP W/ GROUT

<u>DETAIL A</u>

DEMOLITION GENERAL NOTES

DEMOLITION NOTES APPLY TO ALL DEMOLITION SHEETS.

THE CONTRACTOR SHALL:

- A. COORDINATE ALL DEMOLITION AND PHASING EFFORTS WITH THE ARCHITECT AND OWNER'S REPRESENTATIVE. EVERY EFFORT SHALL BE MADE TO MINIMIZE DISRUPTION OF OWNER'S OPERATIONS. EXCESSIVE NOISE OR VIBRATION SHALL BE PRE-APPROVED AND COORDINATED WITH THE OWNER'S
- REPRESENTATIVE. IN ALL CASES, PROVISIONS SHALL BE MADE FOR USER'S SAFETY.
- B. COORDINATE ANY DISRUPTION OF UTILITY SERVICES WITH THE OWNER AND AS SPECIFIED. C. CONSTRUCT TEMPORARY CONSTRUCTION PARTITIONS WITHIN THE EXISTING BUILDING WHICH OFFER A ONE-HOUR ENCLOSURE TO ISOLATE ANY DEMOLITION/CONSTRUCTION WORK FROM THE GENERAL PUBLIC AND AS DEEMED NECESSARY BY THE OWNER AND CODE OFFICIAL HAVING JURISDICTION. COORDINATE LOCATIONS WITH THE OWNER AND MAINTAIN MEANS OF EGRESS THROUGHOUT THE WORK.
- D. MAINTAIN A SECURE, WEATHER-TIGHT ENCLOSURE AT ALL E. VERIFY ALL EXISTING CONDITIONS, DIMENSIONS AND ELEVATIONS AND NOTIFY THE ARCHITECT OF ANY
- DISCREPANCIES. F. REMOVE IN THEIR ENTIRETY ALL EXISTING WALLS, DOORS, MILLWORK, PLUMBING FIXTURES, CEILINGS, SOFFITS, MARKER BOARDS, AND OTHER ITEMS, AS REQUIRED TO EXECUTE THE DEMOLITION/CONSTRUCTION WORK DESCRIBED BY THE
- G. THE OWNER SHALL RESERVE THE RIGHT TO SALVAGE ANY H. PROVIDE PROTECTION FOR ALL EXISTING BUILDING MATERIALS AND EQUIPMENT FROM DAMAGE DUE TO ANY DEMOLITION OR
- CONSTRUCTION-RELATED INCIDENT PERFORMED UNDER THIS
- I. REPAIR OR REPLACE ITEMS THAT ARE DAMAGED AS A RESULT OF DEMOLITION OR CONSTRUCTION TO MATCH EXISTING FINISH AND/OR CONDITION.
- J. EXISTING MATERIALS SHALL NOT BE REUSED UNLESS NOTED OTHERWISE OR AS AUTHORIZED BY ARCHITECT.
- K. VERIFY AND MAINTAIN THE LOCATION OF EXISTING POWER, COMMUNICATION AND DATA CABLES TO PREVENT INTERRUPTION OF THEIR SERVICE.
- L. PATCH FLOOR, WALL AND CEILING PENETRATIONS RESULTING FROM REMOVAL OR RE-ROUTING OF NEW OR EXISTING PIPING,
- DUCTWORK, CONDUIT, AND OTHER ITEMS, AS REQUIRED TO MAINTAIN FIRE-RESISTANCE-RATED SEPARATIONS. FINISH AS REQUIRED FOR NEW OR EXISTING ADJACENT SURFACES.
- M. CAP ALL DISCONNECTED MECHANICAL PIPING LINES WITHIN THE WALL OR FLOOR. PATCH AND FINISH AS REQUIRED TO MATCH NEW OR EXISTING ADJACENT SURFACES.
- N. SEE MECHANICAL AND ELECTRICAL DRAWINGS AND NOTES FOR FURTHER SEQUENCING AND SCOPE OF WORK. O. AVOID ANY DISTURBANCE OF SOILS WITHIN THE ZONE OF
- INFLUENCE AROUND EXISTING FOOTINGS AND FLOOR SLABS AS DIRECTED BY GEOTECHNICAL ENGINEER. P. WHERE CMU WALLS ARE INDICATED TO BE REMOVED, PREPARE
- ADJACENT WALLS TO RECEIVE NEW PATCH/FINISH BY REMOVING CMU IN TOOTH-IN PATTERN BOTH SIDES OF DEMOLITION FOR
- CONTRACTOR TO TOOTH-IN NEW CMU PATCHES. Q. WHERE PLASTER/STUD WALLS ARE INDICATED TO BE REMOVED,
- PREPARE ADJACENT WALLS TO RECEIVE NEW PATCH/FINISH BY SAWCUTTING ADJACENT PLASTER FINISH A MINIMUM OF 1'-0"
- BEYOND DEMOLITION. R. REMOVE WALLS INDICATED BY THE FOLLOWING LINETYPE
- (UNLESS NOTED OTHERWISE):

KEYNOTES - DEMOLITION PLAN - CP241934 DO1 OVERHEAD DOOR AND ASSOCIATED TRACK ABOVE - REMOVE AND

- D03 WALL MOUNTED SPEAKER REMOVE AND SALVAGE TO OWNER D04 SAW CUT AND REMOVE CONCRETE SLAB AND SUBGRADE AS REQUIRED FOR NEW FOOTINGS
- D05 REMOVE EXISTING TURF AND SALVAGE FOR REINSTALLATION UPON COMPLETION OF CONCRETE SLAB

D06 BRICK VENEER, EXTERIOR INSULATION, EXTERIOR SHEATHING AND

- COLD FORMED METAL FRAMING REMOVE AND DISPOSE OF D07 DECORATIVE WALL TILE & SUBSTRATE - REMOVE AND DISPOSE OF D08 MONITOR - REMOVE AND SALVAGE FOR REINSTALLATION
- D09 BRICK VENEER, EXTERIOR INSULATION, AND EXTERIOR SHEATHING -REMOVE AND DISPOSE OF. EXISTING STUD FRAMING, BLACK FRP, AND SSTL POST TO REMAIN - PROTECT DURING CONSTRUCTION
- 10 EXISTING QUARTZ COUNTERTOP REMOVE AND DISPOSE OF 11 RECESSED FLOOR GRILLE SYSTEM - REMOVE AND DISPOSE OF
- D12 METAL BAR FOOT RAIL AND POSTS REMOVE AND SALVAGE FOR
- D13 DRINK RAIL BARRIER WALL AND COUNTERTOP REMOVE AND SALVAGE FOR REINSTALLATION D14 TRENCH DRAIN - REMOVE PER MEP
- D15 GRAPHIC WALLCOVERING REMOVE FOR INSTALLATION OF NEW D16 CMU BLOCK WALL - DEMO PORTION AS REQUIRED FOR MECHANICAL DAMPER INSTALLATION AS INDICATED ON MECHANICAL AND
- D17 METAL TOILET PARTITION AND ASSOCIATED HARDWARE REMOVE AND
- SALVAGE FOR REINSTALLATION D18 TOILET ACCESSORIES - REMOVE AND DISPOSE OF
- D19 PLUMBING FIXTURE REMOVE AND DISPOSE OF AS INDICATED ON

PLUMBING DRAWINGS
01 D20 DOOR - REMOVE AND SALVAGE TO OWNER

THE PROFESSIONAL ARCHITECT'S SEAL ON THIS DRAWING HAS BEEN AFFIXED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 327, RSMO. IN AFFIXING THIS SEAL, THE ARCHITECT WORK SHOWN ON THIS DRAWING
ONLY, AND HEREBY DISCLAIMS
ANY AND ALL RESPONSIBILITY FOR
OTHER PROJECT DRAWINGS NOT
DIRECTLY BEARING THIS SEAL.


Bradley J. Stegemann - Architect


License No. A-2008015243

ISSUE FOR BID

FIELD LEVEL -RECRUITING ROOM - DEMO


A102





TOILET PARTITION DEMO & SALVAGE

SCALE: 1/4" = 1'-0"







ISSUE FOR BID 10/02/2025 ADD-01 10/29/2025

SOA 25042 DETAILS

A601

DOOR AND FRAME SCHEDULE

A. ALL EXTERIOR HOLLOW METAL FRAMES SHALL BE FILLED WITH

B. ALL INTERIOR HOLLOW METAL FRAMES SET IN MASONRY AND

SHALL BE FILLED WITH MINERAL WOOL BLANKET INSULATION. D. ALL EXTERIOR FRAMES SHALL BE INSTALLED WITH 1/4" SHIM

CONCRETE WALLS SHALL BE GROUTED SOLID. C. ALL HOLLOW METAL FRAMES SET IN METAL STUD WALLS

AND SEALANT AROUND PERIMETER OF FRAME.

GENERAL NOTES

INSULATION.


NOTE: EQUAL PANEL SIZE WITH 3'-6" AS ANTICIPATED TYPICAL PANEL WIDTH NOTE: ALL EXTERIOR GLAZING IS CTIG UNLESS NOTED OTHERWISE


RECRUITING PATIO - SOUTH

SCALE: 1/4" = 1'-0" REFER TO SCHEDULE


4'-6" 4'-5" 4'-6" 4'-6" SF1 STOREFRONT ELEVATION TYPES


SCALE: 1/4" = 1'-0"







								DOOR	AND F	RAME	SCHEDU	ILE				
		PANEL					FRAME FIRE				DETAILS					
NUMBER	NO. OF PANELS	WIDTH	HEIGHT	THICKNESS	MATERIAL	GLASS	TYPE	MATERIAL	TYPE	RATING	HARDWARE SET	HEAD	JAMB LEFT	JAMB RIGHT	SILL	COMMENTS
S006A	2	6' - 0"	7' - 0"	1 3/4"	ALUM	CTIG	E2	ALUM	SF1		6	03	04	04		
S006B	6	3' - 5 3/256"	7' - 0"	2"	ALUM	CTIG	Stacking	ALUM			5	03	04	-	02/A.9.1	
S006C	6	3' - 5 3/256"	7' - 0"	2"	ALUM	CTIG	Stacking	ALUM			5	03	-	04	02/A.9.1	
S006D	2	6' - 0"	7' - 0"	1 3/4"	ALUM	CTIG	E2	ALUM	SF1		6	03	04	04		
2006E	2	הי חיי	7' O"	1 2//"	WD		۸.2	шм	1		2	01	01	01		









O1 INT STUD - DOOR HEAD/JAMB DETAIL, TYP

SCALE: 1 1/2" = 1'-0"

A701

DOOR & FRAME

TYPE & SCHEDULE

MEMORIAL STADII SEZ RECRUITING ROOM F UNIVERSITY PROJECT NU

ISSUE FOR BID

10/02/2025

SOA 25042

ADD-01 10/29/2025

DEMOLITION GENERAL NOTES

DEMOLITION NOTES APPLY TO ALL DEMOLITION SHEETS.

THE CONTRACTOR SHALL:

1. COORDINATE ALL DEMOLITION AND PHASING EFFORTS WITH THE ARCHITECT AND OWNER'S REPRESENTATIVE. EVERY EFFORT SHALL BE MADE TO MINIMIZE DISRUPTION OF OWNER'S OPERATIONS. EXCESSIVE NOISE OR VIBRATION SHALL BE PRE-APPROVED AND COORDINATED WITH THE OWNER'S REPRESENTATIVE. IN ALL CASES, PROVISIONS SHALL BE MADE FOR USER'S SAFETY. 2. COORDINATE ANY DISRUPTION OF UTILITY SERVICES WITH THE OWNER AND AS SPECIFIED. 3. CONSTRUCT TEMPORARY CONSTRUCTION PARTITIONS WITHIN THE EXISTING BUILDING WHICH OFFER A ONE-HOUR ENCLOSURE TO ISOLATE ANY DEMOLITION/CONSTRUCTION WORK FROM THE GENERAL PUBLIC AND AS DEEMED NECESSARY BY THE OWNER AND CODE OFFICIAL HAVING JURISDICTION. COORDINATE LOCATIONS WITH THE OWNER AND MAINTAIN MEANS OF EGRESS THROUGHOUT THE WORK. 4. MAINTAIN A SECURE, WEATHER-TIGHT ENCLOSURE AT ALL

5. VERIFY ALL EXISTING CONDITIONS, DIMENSIONS AND ELEVATIONS AND NOTIFY THE ARCHITECT OF ANY DISCREPANCIES. 6. REMOVE IN THEIR ENTIRETY ALL EXISTING WALLS, DOORS,

MILLWORK, PLUMBING FIXTURES, CEILINGS, SOFFITS, MARKERBOARDS, AND OTHER ITEMS, AS REQUIRED TO EXECUTE THE DEMOLITION/CONSTRUCTION WORK DESCRIBED BY THE 7. THE OWNER SHALL RESERVE THE RIGHT TO SALVAGE ANY 8. PROVIDE PROTECTION FOR ALL EXISTING BUILDING MATERIALS AND EQUIPMENT FROM DAMAGE DUE TO ANY DEMOLITION OR CONSTRUCTION-RELATED INCIDENT PERFORMED UNDER THIS

9. REPAIR OR REPLACE ITEMS THAT ARE DAMAGED AS A RESULT OF DEMOLITION OR CONSTRUCTION TO MATCH EXISTING FINISH AND/OR CONDITION. 10. EXISTING MATERIALS SHALL NOT BE REUSED UNLESS NOTED OTHERWISE OR AS AUTHORIZED BY ARCHITECT. 11. VERIFY AND MAINTAIN THE LOCATION OF EXISTING POWER, COMMUNICATION AND DATA CABLES TO PREVENT

INTERRUPTION OF THEIR SERVICE. 12. PATCH FLOOR, WALL AND CEILING PENETRATIONS RESULTING FROM REMOVAL OR RE-ROUTING OF NEW OR EXISTING PIPING, DUCTWORK, CONDUIT, AND OTHER ITEMS, AS REQUIRED TO MAINTAIN FIRE-RESISTANCE-RATED SEPARATIONS. FINISH AS REQUIRED FOR NEW OR EXISTING ADJACENT SURFACES. 13. CAP ALL DISCONNECTED MECHANICAL PIPING LINES WITHIN THE WALL OR FLOOR. PATCH AND FINISH AS REQUIRED TO MATCH NEW OR EXISTING ADJACENT SURFACES. 14. SEE MECHANICAL AND ELECTRICAL DRAWINGS AND NOTES FOR FURTHER SEQUENCING AND SCOPE OF WORK.

15. AVOID ANY DISTURBANCE OF SOILS WITHIN THE ZONE OF INFLUENCE AROUND EXISTING FOOTINGS AND FLOOR SLABS AS DIRECTED BY GEOTECHNICAL ENGINEER. 16. E.C. SHALL BE RESPONSIBLE FOR OBTAINING ALL NECESSARY PERMITS AND FOLLOWING THE REQUIREMENTS FOR DEMOLITION WORK WORK WITHIN THE GOVERNING MUNICIPALITY. E.C. SHALL BE TOTALLY RESPONSIBLE FOR SAFE PROCEDURES, PRACTICES, AND OPERATION. FOR ALL EXISTING ELECTRICAL DEVICES TO BE REMOVED. E.C. SHALL PROTECT ALL SURFACES, FURNISHINGS, EQUIPMENT, ETC. ADJACENT TO DEMOLITION AREAS FROM DAMAGE. 17. FOR ALL EXISTING ELECTRICAL DEVICES AND LIGHT FIXTURES

TO BE REMOVED, E.C. SHALL VERIFY PANEL AND CIRCUIT NUMBERS IN THE EXISTING ELECTRICAL PANELS AND ISOLATE WIRING AT THE BREAKERS. CONTRACTOR SHALL REMOVE ALL CABLE AND ACCESSIBLE EXPOSED CONDUIT BETWEEN END DEVICE AND IT'S UPSTREAM POWER SOURCE, REMOVE ALL ELECTRICAL APPURTENANCES (DISCONNECT, STARTER, WIRING, ONDUIT. CONDUIT STRAPS. ETC.) ASSOCIATED WITH THE DEVICE AND / OR EQUIPMENT THAT IS BEING REMOVED, PROVIDE BLANK METAL COVER PLATES FOR ALL JUNCTION BOXES NO LONGER IN USE THAT ARE EMBEDDED IN CONCRETE OR MASONRY WALLS. PROVIDE PLUGS FOR ALL PANELS WHERE CONDUIT HAS BEEN REMOVED. COVER PLATES SHALL BE PAINTED TO MATCH EXISTING CONDITIONS.

18. REFER TO SPECIFICATIONS FOR REMOVAL AND ABATEMENT REQUIREMENTS OF HAZARDOUS ENVIRONMENTAL CONDITIONS. 19. CONTRACTOR SHALL PROVIDE ALL LABOR AND MATERIALS AND RELOCATION REQUIRED TO MAINTAIN ALL ELECTRICAL CIRCUITS TO AREAS OUTSIDE DEMOLITION. 20. PATCH HOLES AFTER REMOVAL OF ELECTRICAL EQUIPMENT IN AREAS OF DEMOLITION. NOT ALL EQUIPMENT MAY BE SHOWN.

CONTRACTORS SHALL VISIT THE SITE BEFORE BIDDING AND BECOME FAMILIAR WITH THE SCOPE OF DEMOLITION. 21. EXISTING ELECTRICAL SYSTEMS LAYOUT, LOCATION AND SIZES ARE BASED ON AS-BUILT DOCUMENTS AND LIMITED FIELD SURVEYS. DUE TO HIDDEN CONDITIONS AT A TIME OF SURVEY, CONTRACTOR SHALL ADVISE ENGINEER OF RECORD OF ANY FIELD CONDITIONS OF AFFECTED SYSTEMS THAT ARE NOT REFLECTED IN SET OF DOCUMENTS PRIOR TO DEMOLITION OF THE SYSTEM AND BEFORE THE START OF NEW WORK TO THE SYSTEM. PROVIDE MATCHING BLANK COVER PLATES WHERE DEVICES ARE BEING REMOVED FROM EXISTING WALLS TO

22. EXISTING MEP SYSTEM ROUTINGS AND LOCATIONS SHOWN ARE AN APPROXIMATION BASED ON FIELD OBSERVATION AND EXISTING BUILDING MEP CONSTRUCTION DOCUMENTS. CONTRACTOR SHALL FIELD VERIFY EXACT LOCATION OF EXISTING MEP SYSTEMS TO REMAIN AND BE DEMOLISHED PRIOR TO STARTING WORK. 23. REFER TO ASBESTOS SURVEY / REPORT DATED 11/25/2024 FOR AREAS CONTAINING ASBESTOS WHERE DEMOLITION WILL OCCUR. REFER TO ASBESTOS SURVEY CONTRACTOR RECOMMENDATIONS AND DETAILS FOR REMOVAL. 24. COORDINATE WITH OWNERS REP AT LEAST 72 HOURS IN

ADVANCE OF ALL OUTAGES. ATHLETIC MAINTENANCE STAFF WILL PROBABLY BE INVOLVED IN ALL THE SHUTOFFS UNLESS IT IS PART OF THE UTILITIES SERVICE. THEN IT WILL BE ENERGY

SHEET NOTES REMOVE, SALVAGE, AND RETURN LIGHT FIXTURE TO OWNER. DEMO CONDUIT / CONDUCTORS BACK TO NEAREST J-BOX ABOVE CEILING.

2 REMOVE AND SALVAGE EXITING SUPPLY DUCT STATIC
PRESSURE SENSOR. COIL UP WIRE FOR RE-INSTALLATION.

4 DEMOLISH FLOOR DRAIN / TRENCH DRAIN AND CAP/ PREPARE FOR NEW CONNECTION. SEE P102

3 DEMOLISH DASHED DUCTWORK. SOFFIT TO BE DEMOLISHED AS REQUIRED. SEE ARCHITECTURAL PLANS FOR DETAILS.

KEY PLAN

SHANE L. FLOYD OCT. 29, 2025

THE PROFESSIONAL ARCHITECT'S SEAL ON THIS DRAWING HAS BEEN AFFIXED IN ACCORDANCE WITH THE REQUIREMENTS OF

CHAPTER 327, RSMO. IN AFFIXING THIS SEAL, THE ARCHITECT

WORK SHOWN ON THIS DRAWING ONLY, AND HEREBY DISCLAIMS ANY AND ALL RESPONSIBILITY FOR

OTHER PROJECT DRAWINGS NOT DIRECTLY BEARING THIS SEAL.

PE-2019017814

ISSUE FOR BID

FIELD LEVEL -RECRUITING - MEP DEMOLITION PLAN

MED102

ELECTRICAL NEW WORK GENERAL NOTES

NOTES APPLY TO ALL ELECTRICAL NEW WORK SHEETS.


THE CONTRACTOR SHALL:


1. REFER TO E002 FOR REMAINING LIGHTING NOTES, LEGENDS, DETAILS & SCHEDULES. 2. CONDUIT ROUTINGS ARE SHOWN FOR REFERENCE ONLY AND TO ESTABLISH INTENT AND A POTENTIAL ROUTING IN COORDINATION WITH EXISTING

CEILING SYSTEMS. CONTRACTOR SHALL FIELD VERIFY EXACT ROUTINGS 3. EXISTING CEILING SYSTEMS AND HEIGHTS REFERENCED ARE BASED ON EXISTING RECORD DOCUMENTS OF THE SOUTH END ZONE. CONTRATCOR SHALL FIELD VERIFY EXISTING HEIGHTS FOR CONTUIT ROUTINGS PRIOR TO

INSTALL NEW SURFACE MOUNTED RECEPTACLE AND CONNECT TO EXISTING RECEPTACLE CIRCUIT AS REQUIRED.

- SURFACE-MOUNT CONDUIT TO WALL. 2. INSTALL NEW RECEPTACLE AT 72" AFF FOR WALL-MOUNTED
- PILLAR. CONNECT TO EXISTING 120V RECEPTACLE CIRCUIT IN THE PILLAR OR SERVING TV OUTLETS IN THE ADJACENT WALL. 3. INSTALL NEW RECESSED LIGHT FIXTURE. TIE INTO EXISTING
- 4. INSTALL NEW SURFACE MOUNTED LIGHT IN TABLE STORAGE ROOM. WIRE THRU EXISTING LIGHTING CIRCUIT SERVING
- 5. NEW GFI RECEPTACLE AND DATA OUTLET FOR TELEVISION
- MOUNTED TO COLUMN. COORDINATE MOUNTING HEIGHT WITH TELEVISION INSTALLER. POWER THRU NEARBY CIRCUIT
- 6. ROUTE CIRCUIT FOR NEW VAV BOX TO NEW 30A-3B BREAKER IN EXISTING PANEL 'D3N-S-MSB'. SEE OVERALL PLAN FOR PANEL
- SPEAKER/STROBE. EXTEND NOTIFICATION APPLIANCE STROBE AND SPEAKER CIRCUITS FROM EXISTING SPEAKER/STROBE AS
- 8. CONDUIT AND CONDUCTORS FOR NEW VAV BOX ELECTRIC HEAT. ROUTE SURFACE MOUNTED TO WALL AS HIGH AS POSSIBLE, FOLLOWING THE CHANGE IN STRUCTURE ELEVATION.
- CONDUIT SHALL BE PAINTED TO MATCH THE WALL SURFACE COLOR THAT THE CONDUIT IS MOUNTED TO. ROUTING SHOWN IS APPROXIAMTE. CONTRACTOR SHALL FIELD VERIFY PRIOR TO ORDERING MATERIALS. COORDINATE WITH EXISTING MECHANICAL, SPRINKLER, PLUMBING, FIRE ALARMS AND
- 9. ROUTE NEW 12 GA. SPEAKER WIRE ON EXISTING CABLE TRAY THAT FOLLOWS THE APPROXIMATE ROUTING SHOWN. ROUTING SHOWN IS APPROXIMATE AND CONTRACTOR SHALL FIELD VERIFY LOCATION OF CABLE TRAY AND ROUTING PRIOR TO ORDERING MATERIALS. CONTRACTOR SHALL FIELD VERIFY
- EXISTING SPEAKER WIRE CABLE TYPE AND PROVIDE NEW SAME 11. EXISTING CEILING THIS ROOM IS BEING REMOVED FOR HVAC WORK. LIGHT FIXTURES AND LIGHTING CONTROL DEVICES
- SHALL SUSPEND IN PLACE AND BE INSTALLED IN NEW CEILING AS SAME APPROXIMATE LOCATION. 12. EXISTING SPEAKER LOCATION. COORDINATE WITH AUDIO
- TO REPROGRAM THIS SPEAKER TO BE ON THE INTERIOR RECRUITING SPACE AUDIO ZONE. COORDINATE SPEAKER REPLACEMENT WITH AUDIO REPRESENTATIVE.
- 13. NEW EXTERIOR SPEAKER LOCATION. COORDINATE WITH AUDIO COMPANY REPRESENTATIVE AND MU AUDIO REPRESENTATVE TO PROGRAM THIS SPEAKER TO BE ON THE EXTERIOR
- 14. NEW 1" CONDUIT WITH NEW 12 GA. SPEAKER WIRE. (1) NEW SPEAKER WIRE PER NEW SPEAKER LOCATION.





THE PROFESSIONAL ARCHITECT'S SEAL ON THIS DRAWING HAS BEEN AFFIXED IN ACCORDANCE WITH THE REQUIREMENTS OF CHAPTER 327, RSMO. IN AFFIXING THIS SEAL, THE ARCHITECT WORK SHOWN ON THIS DRAWING
ONLY, AND HEREBY DISCLAIMS
ANY AND ALL RESPONSIBILITY FOR
OTHER PROJECT DRAWINGS NOT
DIRECTLY BEARING THIS SEAL.


ISSUE FOR BID

RECRUITING ROOM -ELECTRICAL PLANS

KEY PLAN

E102

angle



PLUMBING NEW WORK GENERAL NOTES

- NOTES APPLY TO ALL PLUMBING NEW WORK SHEETS.
- THE CONTRACTOR SHALL:
- A. REFER TO P002 FOR REMAINING LIGHTING NOTES, LEGENDS, DETAILS & B. FIELD VERIFY ALL NEW WATER, WASTE, AND VENT PIPING CONNECTIONS
- AND PROVIDE NEW CONNECTIONS AS REQUIRED FOR PROPERLY OPERATING SYSTEMS. C. PITCH UNDERFLOOR SANITARY WASTE PIPING 4" AND GREATER AT 1/8" PER
- FOOT, UNLESS NOTED OTHERWISE. PITCH ALL OTHER SANITARY WASTE PIPING AT 1/4" PER FOOT UNLESS OTHERWISE NOTED.
- D. FIELD VERIFY LOCATION AND INVERTS OF SITE UTILITIES PRIOR TO INSTALLATION. OTHERWISE, REFER TO CIVIL PLANS. E. WASTE AND VENT PIPING BELOW FLOOR AND THROUGH FLOOR SHALL BE 3"
- F. PROVIDE CLEANOUT IN ACCESSABLE LOCATION AT THE BASE OF ALL
- G. ALL EXISTING PLUMBING ROUTING AND LOCATIONS SHOWN (HALF TONE)
- ARE AN APPROXIMATION BASED ON FIELD OBSERVATIONS AND EXISTING BUILDING PLANS. CONTRACTOR SHALL CAMERA SANITARY SEWER AND VERIFY EXISTING ROUTING, LOCATION, DEPTH, HEIGHT, AND PIPE SIZE TO
- H. ALL EXISTING WALLS ARE BLOCK AND PIPE PENETRATIONS SHALL BE CORE DRILLED UNLESS NOTED OTHERWISE. SEE ARCHITECTURAL DEMOLITION PLANS FOR WALLS TO REMAIN AND TO BE DEMOLISHED. I. UPON DEMOLITION OF EXISTING PLUMBING CHASE WALLS, CONTRACTOR SHALL FIELD LOCATE EXTISTING SANITARY CLEANOUTS / END OF ABOVE GRADE SANITARY RUNS AND INFORM ARCHITECT AND ENGINEER OF PLACEMENTS FOR COORDINATION OF ACCESS PANELS. J. ALL VALVES SHALL BE ACCESSIBLE FROM THE FLOOR

GENERAL FIRE PROTECTION NOTES 1. ALL WORK & MATERIALS SHALL BE IN COMPLIANCE WITH STATE & LOCAL CODE REQUIREMENTS. SUBCONTRACTOR SHALL OBTAIN & PAY FOR ALL PERMITS &

- INSPECTION FEES AS NECESSARY FOR CONSTRUCTION. 2. ALL FIRE PROTECTION SYSTEMS & COMPONENTS SHALL BE IN COMPLIANCE WITH NFPA SECTIONS 13, & 24 AS WELL AS LOCAL FIRE PREVENTION REQUIREMENTS.
- 3. FIRE SPRINKLER CONTRACTOR SHALL VERIFY WITH CURRENT NFPA THE SPRINKLER HEAD SPACING & DENSITY FOR ALL OCCUPANCY TYPES.
- 4. SUBCONTRACTOR SHALL DO ALL NECESSARY CUTTING & PATCHING, AS WELL AS
- ALL NECESSARY PIPE & EQUIPMENT SUPPORTS. 5. PRESSURE TEST MODIFICATIONS TO EXISTING SYSTEM & REPAIR ANY LEAKS.
- CAUSED BY FAULTY INSTALLATION OR MATERIALS. 6. THE SPRINKLER SUBCONTRACTOR SHALL REFER TO PLANS & MAKE ADJUSTMENTS TO NUMBER, TYPE, & LOCATION OF HEADS, TO COMPLY WITH LOCAL CODES & NEW CONSTRUCTION. HE SHALL ALSO COORDINATE HIS FINAL SHOP DRAWINGS WITH THE OTHER TRADES TO AVOID CONFLICT WITH HIS PIPING & THE LIGHTS, PIPING, CONDUITS, & DUCTWORK OF OTHER RESPECTIVE SUBCONTRACTORS ON THIS

SUBCONTRACTOR IS RESPONSIBLE FOR ANY DAMAGE TO PROPERTY & PERSONNEL

PE-2019017814

THE PROFESSIONAL ARCHITECT'S SEAL ON THIS DRAWING HAS BEEN AFFIXED IN ACCORDANCE WITH THE REQUIREMENTS OF

CHAPTER 327, RSMO. IN AFFIXING THIS SEAL, THE ARCHITECT

WORK SHOWN ON THIS DRAWING
ONLY, AND HEREBY DISCLAIMS
ANY AND ALL RESPONSIBILITY FOR
OTHER PROJECT DRAWINGS NOT
DIRECTLY BEARING THIS SEAL.

BE SUBMITTED FOR OWNER'S APPROVAL FOR ALL SPRINKLER SYSTEM MODIFICATIONS. 7. AS REQUIRED, FIRE STOPPING SHALL BE DONE BY METHODS REQUIRED BY LOCAL AUTHORITIES. FIRE STOP MATERIALS SHALL BE HILTI SILICONE ELASTOMER OR

PROJECT. SHOP DRAWINGS & APPLICABLE HYDRAULIC CALCULATIONS THAT ARE SEALED BY A FIRE PROTECTION CONSULTANT & PROFESSIONAL ENGINEER SHALL

8. PROVIDE FIRE STOPPING AT ALL FLOOR & WALL PENETRATIONS. 9. SUBMIT CERTIFICATION UPON COMPLETION OF FIRE PROTECTION PIPING WORK WHICH INDICATES THAT WORK HAS BEEN TESTED IN ACCORDANCE WITH NFPA 13,

AND ALSO THAT THE SYSTEM IS OPERATIONAL. COMPLETE. AND WITHOUT


10. PROVIDE REQUIRED UNDERGROUND WATER SERVICE LINE AT THE LOCATION(S) INDICATED ON THE DRAWING, CONSULT WITH THE CITY WATER DEPARTMENT AND LOCAL AUTHORITIES WITH RESPECT TO NECESSARY MATERIALS AND LABOR TO CONFORM WITH ALL LOCAL REQUIREMENTS.

DEFECTS.

- 11. PROVIDE FIRE DEPARTMENT CONNECTION THROUGH EXTERIOR BUILDING WALL WHERE SHOWN ON THE PLANS. COORDINATE THE EXACT LOCATION, PIPE THREADS AND FITTINGS WITH THE LOCAL FIRE DEPARTMENT TO ENSURE EXACT MATCH. 12. SPRINKLER HEAD TEMPERATURE RATINGS SHALL BE APPROPRIATE FOR THE AMBIENT CONDITIONS IN THE IMMEDIATE AREAS.
- 13. INSTALL HANGERS AND SUPPORTS FOR SPRINKLER PIPING ACCORDING TO NFPA 13. COMPLY WITH REQUIREMENTS FOR HANGER MATERIALS IN NFPA 13.
- 14. ALL SPRINKLER HEADS IN AREAS WITH CEILINGS SHALL BE THE FULL CONCEALED 15. FIRE SPRINKLER PIPE ROUTING IS SHOWN TO REPRESENT APPROXIMATE PATH AND
- ROUTING. FIRE SPRINKLER CONTRACTOR SHALL VERIFY EXACT ROUTING, HEIGHTS, AND SIZING AND SUBMIT VIA DEFERRED SUBMITTAL.


DEFERRED SUBMITTAL NOTES

- 1. FIRE SPRINKLER SYSTEM SHALL BE A DEFERRED SUBMITTAL BY FIRE SPRINKLER CONTRACTOR. INFORMATION REQUIRED TO BE TURNED INTO THE AHJ INCLUDES THE FOLLOWING, TWO SETS HYDRAULIC CALCULATIONS, AND SPRINKLER DRAWINGS SEALED BY A LICENSED PROFESSIONAL ENGINEER OF THE STATE OF
- 1 6" SPRINKLER PIPE (ETR) SHOWN FOR REFERENCE ONLY. 2 SPRINKLER PIPE (ETR) SHOWN FOR REFERENCE ONLY. 3 ROUTE NEW SPRINKLER PIPE ABOVE LIGHTS AND ROUTE TO FOLLOW TIGHT TO
- THE SLOPE OF STRUCTURE IN THIS ROOM. 4 CORE DRILL THRU BLOCK WALL TO ROUTE NEW SPRINKLER PIPE THRU WALL ABOVE ADDITION CEILNIG SPACE (MIN. 8'-4 AFF). COORDINATE LOCATION WITH
- EXISTING MEP AND LOW VOLTAGE SYSTEMS CURRENTLY INSTALLED. 5 ROUTE NEW SPRINKLER PIPING ABOVE CEILING OF NEW ADDITION SPACE (MIN. 8'-4 AFF). ROUTING IS SHOWN TO REPRESENT APPROXIMATE PATH AND ROUTING. FIRE SPRINKLER CONTRACTOR SHALL VERIFY EXACT ROUTING, HEIGHTS, AND SIZING AND SUBMIT VIA DEFERRED SUBMITTAL.



1. THIS DETAIL APPLIES TO ALL PIPES. THE INTENTION IS TO CONTINUE THE INSULATION AND VAPOR BARRIER THROUGH ALL PENETRATIONS. PERMIT THERMAL EXPANSION WITHOUT DAMAGING INSULATION, AND TO SEAL AIRTIGHT AROUND INSULATED AND UNISULATED PIPES FOR NOISE TRANSMISSION CONTROL. 2. FLOOR OPENINGS ARE SIMILAR SEE SPEC

6 WALL PENETRATION - NON-FIRE RATED NTS



FIELD LEVEL -RECRUITING -PLUMBING & FIRE PROTECTION PLAN

ISSUE FOR BID