

TO CONTRACT DOCUMENTS ENTITLED:

PROJECT MANUAL FOR:
The University of Missouri
Memorial Student Union
Rooftop Duct Replacement

PROJECT NUMBER: CP252991 / IMEG #25007028.00

ADVERTISEMENT DATE: March 19, 2026

PREPARED FOR: The Curators of the University of Missouri

CONSULTANT: Tony Zehnle
IMEG
15 Sunnen Dr, Suite 104
St. Louis, MO 63143
314-435-6963

Drawings and Specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

SPECIFICATION CHANGES:

1. **The bid date has been changed to Tuesday, April 7, 2026 - 1:30 p.m. CST.**
2. Division 1.E, Section 8:
 - a. **ADD** d. Contractor shall protect roof in area of work or storage with 1” polyiso and 1/2” plywood.

DRAWING CHANGES:

1. V400 – Ventilation Details
 - a. **ADD** Note 5 to allow intermediate supports that are not anchored to the roof deck per page 13 of the Thermaduct contractor installation manual.
2. V702 – Return Duct Shop Drawing
 - a. **REMOVE** notes about duct in gray being customer-provided. All exposed rooftop duct is provided by the Owner under warranty through Thermaduct as noted in section 1.A.4.c.1 of the specifications.

END OF ADDENDUM #1